



MONITORING OF EMISSIONS FROM THE RANHEAT BOILER & WET SPRAYBOOTH PROCESSES

Prepared for Alan Nuttall Ltd

Installation: Dudley

**Date of Monitoring Visit:
8-9 April, 2015**

REC Report EM-02818p1r0



a CONCEPT LIFE SCIENCES company





Opinions and interpretations expressed herein are outside the scope of UKAS accreditation
This report should not be reproduced except in full without the written approval of REC Ltd
Sampling identified as UKAS accredited was conducted in accordance with REC Ltd accredited Monitoring Methods.
Analyses identified as UKAS accredited were conducted by REC or approved sub-contractors in accordance with their SOPs

Prepared for:

Alan Nuttall Ltd
National Works
Hall Street
Dudley
DY2 7DQ

Prepared by:

REC Ltd
Unit 19 Bordesley Trading Estate
Bordesley Green Road
Birmingham
B8 1BZ
Tel : 0121 326 7007
Fax : 0121 328 1689
E-mail : sales@recltd.co.uk
Web :www.recltd.co.uk

Issued : 12 May, 2015

A handwritten signature in black ink, appearing to read 'M Edwards'.

Prepared by : _____
Michelle Edwards, Team Leader
MM05 659, MCERTS Level 2, TE1-4

A handwritten signature in black ink, appearing to read 'D. L. Myers'.

Reviewed by : _____
Derek Myers, Operations Manager
MM02 115, MCERTS Level 2 TE1-4

CONTENTS	Page No.
PART 1: EXECUTIVE SUMMARY	4
Objectives of Monitoring	4
Monitoring Results	5
Operating Information	6
Monitoring Deviations	7
PART 2 SUPPORTING INFORMATION	8
APPENDIX 1	8
Sampling Personnel	8
Method Details	8
Monitoring Equipment	9
FURTHER APPENDICES	
2 Stack Diagrams & Description (2 x Additional Pages)	
3 Flow Data (5 x Additional Pages)	
4 Preliminary Gas Measurements & Water Vapour Results (2 x Additional Pages)	
5 Gas Analyser Calibration Measurements (3 x Additional Pages)	
6 Gas Analyser Results (3 x Additional Page)	
7 Laboratory Certificates of Analysis (5 x Additional Pages)	
8 Manual Monitoring Results (19 x Additional Pages)	
9 Uncertainty Calculations (7 x Additional Pages)	

PART 1: EXECUTIVE SUMMARY

Objectives of Monitoring

Resource & Environmental Consultants (REC) Ltd was commissioned by Alan Nuttall Ltd to monitor emissions of pollutants from released from various process stacks at their site in Dudley.

The operations at Alan Nuttall Ltd are authorised under a Part B permit issued by the Local Authority under the Environmental Permitting Regulations, 2010. The site must demonstrate compliance with the emission limits stipulated in the site permit ref. PB/33.

Monitoring has been undertaken for the following parameters:-

Emission Parameter	Emission Point Identification	
	Wet Spray Booth	Ranheat Boiler
Total Particulate Matter	✓	✓
Hydrogen Chloride (as HCl)	-	✓
Formaldehyde	-	✓
Oxygen (O ₂)	-	✓
Carbon Monoxide (CO)	-	✓
Total VOCs (as C)	-	✓
Hydrogen Cyanide	-	✓

Monitoring was undertaken during normal process operations.

Monitoring Results

Emission Point Reference	Parameter	Emission Limit	Monitoring Result	Uncertainty	Units	Reference conditions	Date of Sampling	Start & End Times	Reference Method	Accreditation Status ⁽¹⁾	Operating Status
Wet Spray Booth	Particulates	50	9.8	±1.4	mg/m ³	STP, Wet	08/04/15	11:14-11:54	BS EN 13284	B	Normal
Ranheat Boiler	Particulates	200	89.9	±3.8	mg/m ³	STP, Wet	09/04/15	12:35 – 13:05	BS EN 13284	B	Normal
	HCl	100	25.4	±3.1	mg/m ³	STP, Wet	09/04/15	12:35 – 13:05	BS EN 1911	B	Normal
	Formaldehyde	5	<0.07	±<0.01	mg/m ³	STP, Wet	09/04/15	13:46 – 14:16	US EPA M316A	B	Normal
	HCN	5	<0.1	N/A	mg/m ³	STP, Wet	09/04/15	13:31-14:11	US EPA CTM33	E	Normal
	CO	250	54.4	±2.2	mg/m ³	STP, Wet	09/04/15	12:35 – 13:35	BS EN 15058	A	Normal
	O ₂	None Set	13.5	±0.4	%vol.	STP	09/04/15	12:35 – 13:35	BS EN 14789	A	Normal
	Total VOCs (as C)	20	12.3	±1.7	mg/m ³	STP, Wet	09/04/15	12:35 – 13:35	BS EN 12619	A	Normal

NOTE (1) : UKAS/MCERTS status:- (A) REC Ltd accredited for sampling and analysis. (B) REC Ltd accredited for sampling only, UKAS accredited analysis conducted by SAL or RPS. (E) REC Ltd not accredited for sampling, sub-contracted analysis conducted by SAL not UKAS accredited.

Operating Information

Emission Point Reference	Date	Process Type	Process Duration	Fuel Type	Feedstock	Load	Abatement Plant	Comparison of Operator CEMS and Periodic Monitoring Results			
								Substance	CEMS Results	Monitoring Results	Units
Wet Spray Booth	08/04/15	Spray Booth	Batch	Electricity	Furniture Fittings	Normal	None	N/A	N/A	N/A	N/A
Ranheat Boiler	09/04/15	Wood Burning Boiler	Continuous	Natural Gas	Laminated Scrap Wood	Normal	None	N/A	N/A	N/A	N/A

Monitoring Deviations

Emission Point Reference	Substance Deviations	Monitoring Deviations	Other Relevant Issues
Wet Spray Booth	None	None	<p>The flow and temp variations were within requirements of EA TGN M1</p> <p>Single four inch BSP socket was installed on the stack. EA TGN M1 requires 2 x 5 inch BSP sockets to be fitted at least 5 x hydraulic diameters from any flow disturbance both upstream and downstream of the sampling plane.</p>
Ranheat Boiler	None	<95% of HCl detected in Impingers 1 & 2, probably due to very low concentration of target pollutant.	<p>The flow and temp variations were within requirements of EA TGN M1.</p> <p>Only four inch BSP sockets were installed on the stack. EA TGN M1 requires 5 inch BSP sockets to be fitted at least 5 x hydraulic diameters from any flow disturbance both upstream and downstream of the sampling plane.</p>

PART 2 SUPPORTING INFORMATION

APPENDIX 1

Sampling Personnel

Monitoring was conducted by the following REC Ltd permanent staff:-

- David Burns - Team Leader, MM05 579., MCERTS Level 2, TE1-4
- Michelle Edwards - Assistant, MM05 659, MCERTS Level 2, TE1-4

Method Details

The following table shows the reference methods used for the emissions monitoring survey:

Species	UKAS/ MCERTS Status	Method	Uncertainty ±%	Limit of Detection
Moisture	A	In house method MM0010 based on BS EN 14790	20	0.1%vol
Particulates	B	In house method MM0004 based on BS EN 13284	10	1 mg/m ³
Hydrogen Chloride	B	In house method MM0006 based on BS EN 1911	20	0.1 mg/m ³
Formaldehyde	B	In house method MM0015 based on US EPA M316A	20	0.1 mg/m ³
Hydrogen Cyanide	E	Based on US EPA CTM33	30	0.1 mg/m ³
Carbon Monoxide	A	In house method MM0002 based on BS EN 15058	10	1 mg/m ³
Oxygen	A	In house method MM0002 based on BS EN 14789	10	0.1%vol
Total VOCs (as C)	A	In house method MM0002 based on BS EN 12619	10	1 mg/m ³
Flows	A	In house method TPM01A based on EA MID BS EN 16911	10	5Pa

NOTE (1) : UKAS/MCERTS status:- (A) REC Ltd accredited for sampling and analysis. (B) REC Ltd accredited for sampling only, UKAS accredited analysis conducted by SAL or RPS. (E) REC Ltd not accredited for sampling, sub-contracted analysis conducted by SAL not UKAS accredited.

Monitoring Equipment

All monitoring equipment used at Alan Nuttall Ltd was calibrated before use either externally or in accordance with in house calibration procedures. The equipment used for the testing for each stack identified by its unique AQ No. is shown below.

Equipment	Identification	
Nozzle(s)	AQ	153
Probes(s)	No.	14
Pitot(s)	AQ	104
Timer	AQ	308
Glassware Set	Birmingham Set 1 & Mini Impingers	
Thermocouple(s)	AQ	148, 301
Temperature Indicator	AQ	126,163
Control Console	AQ	126
Manometer	AQ	126
Tape Measure	AQ	278
Balance	AQ	090
FID	AQ	270
Horiba	AQ	268
Cylinders		VC8179253 - Nitrogen VC10044 - Zero Air VCSMG5960 – O ₂ & CO VCDY0207 –C ₃ H ₈
DGM	AQ	199
Heated Line	AQ	315
Heated Line Controller	AQ	316b
Barometer	AQ	344


===== END OF REPORT =====

APPENDIX 2


RANHEAT BOILER & WET SPRAY BOOTH

STACK DIAGRAMS & DESCRIPTION

Stack Ref	Wet Spray Booth
------------------	------------------------



Sample Points



Stack Dimensions:

85cm Diameter

Sample Point Description

A single 4" BSP sampling port was installed on a horizontal plane. The sampling points provided were less than 4 x hydraulic diameters from any flow disturbance both upstream and downstream from the sampling plane.

Due to the absence of a second sampling port, sampling could only be carried out across one sampling plane. The number of sampling points along this plane, were however doubled.


Access was via small temporary scaffolding.

Both the port size and sample planes do not fully meet the requirements stated in Environment Agency Technical Guidance Note M1.

Stack Ref	RANHEAT BOILER
------------------	-----------------------



Sample Points



Stack Dimensions:

22cm Diameter

Sample Point Description

On the Wood Burning Boiler stack 2 x 4" BSP sampling ports were installed at 90° to each other on a horizontal plane. The sampling points provided were less than 4 x hydraulic diameters from any flow disturbances both upstream and downstream from the sampling plane.

Due to access restrictions, only a single sampling plane could be utilised, However this was deemed suitable for the size of the ducting.

Access was via a temporary platform.

Both the port size and sample plane do not fully comply with the positional requirements of Environment Agency Technical Guidance Note M1 (EA TGN M1).

APPENDIX 3

RANHEAT BOILER & WET SPRAY BOOTH

FLOW DATA

APPENDIX 3.1

FLOW DATA

Stack Ref.	Stack Temp	Av Pitot ΔP	Duct Diam	X-Sect. Area	Velocity (actual)	Volume Flow (m ³ /hr)	
	(°C)	(Pa)	(cm)	(m ²)	(m/s)	(actual)	(@ ntp)
Wet Spray Booth	14	20	80	0.503	4.4	7,894	7,465
Ranheat Boiler	130	69	22	0.038	10.5	1,441	974

PRELIMINARY TRAVERSE DATA RECORDING SHEET (CIRCULAR DUCTS)

Site Reference	ALA 6M-1P02818
Site Name	ALAN NUTTALS
Stack Reference	WOOD BURNER BOILER
Date	09/04/15
Time	08:58
Staff	AW/HB

Stack Diameter	0.22	m
Static pressure	-27	mmH ₂ O Pa
Barometric pressure	101.3	mbar
Pitot Cp	0.8404	
Oxygen		%
Moisture	73	%

Stagnation Pressure Check (S Type Pitot) (Difference between Leg A and B must be < 10Pa or < 1mmH₂O)

Leg A	27	Pa
Leg B	25	Pa

ΔP units	Pa	or	mmH ₂ O
----------	----	----	--------------------

Velocity Traverse

Traverse Point	Traverse %	Depth cm	ΔP,1	ΔP,2	ΔP,3	ΔP,ave	T,1 °C	T,2 °C	T,3 °C	T,ave °C	Angle °
1	2.1	0.5	/	/	/		130	/	/	/	/
2	6.7	1.5	/	/	/		130	/	/	/	/
3	11.8	2.6	/	/	/		130	/	/	/	/
4	17.7	3.9	/	/	/		130	/	/	/	/
5	25	5.5	64	65	67	65.3	130	130	130	130	<15°
6	35.6	7.8	66	68	68	67.3	130	130	130	130	<15°
7	64.4	14.2	70	72	71	71.0	130	130	130	130	<15°
8	75	16.5	72	74	75	73.7	130	131	131	131	<15°
9	82.3	18.1	/	/	/		/	/	/	/	/
10	88.2	19.4	/	/	/		/	/	/	/	/
11	93.3	20.5	/	/	/		/	/	/	/	/
12	97.9	21.5	/	/	/		/	/	/	/	/
Traverse Point	Traverse %	Depth cm	ΔP,1	ΔP,2	ΔP,3	ΔP,ave	T,1 °C	T,2 °C	T,3 °C	T,ave °C	Angle °
1	2.1										
2	6.7										
3	11.8										
4	17.7										
5	25										
6	35.6										
7	64.4										
8	75										
9	82.3										
10	88.2										
11	93.3										
12	97.9										

An electronic manometer was used to provide a direct reading of average differential pressure over at least 1 minute

Sampling plane requirements Re: BS EN 13284-1:2001 5.2

Angle of gas flow less than 15° with regard to duct axis	/
No local negative flow	/
Minimum pitot greater than 5Pa	/
Minimum local gas velocity	10.8
Maximum local gas velocity	10.9
Ratio of highest to lowest local gas velocity	1.06

Pitot	104
Manometer	125 PIOS
Temperature ind.	148.4
Thermocouple	148
Barometer	344
Timer	30.8

BS EN 13284-1:2002 Sampling Points

Range of Sampling plain areas (m ²)	Range of Duct Diameters (m)	Minimum Number of Sampling lines (diameters)	Minimum Number of Sampling Points per plane
<0.1	0.35		1a
0.1 to 1.0	0.35 to 1.1	2	4
1.1 to 2.0	1.1 to 1.6	2	8
>2.0	>1.6	2	At least 12 and 4 per m ²⁰

^a Using only one sampling point may give rise to errors greater than those specified in the method and the standard

^b For Large ducts, a number of 20 sampling points is generally sufficient.

Tangential Rule Sampling Points

Sample Point Number	% Along Traverse			
	n=2	n=4	n=6	n=8
1	14.6	6.7	4.4	3.3
2	85.4	25	14.6	10.5
3		75	29.6	19.4
4		93.3	70.4	32.3
5			85.4	67.7
6			95.6	80.6
7				89.5
8				96.7

Sample Point Number	% Along Traverse			
	n=10	n=12	n=14	n=16
1	2.6	2.1	1.8	1.6
2	8.2	6.7	5.7	4.9
3	14.6	11.8	9.9	8.5
4	22.6	17.7	14.6	12.5
5	34.2	25	20.1	16.9
6	65.8	35.6	26.9	22
7	77.4	64.4	36.6	28.3
8	85.4	75	63.4	37.5
9	91.8	82.3	73.1	62.5
10	97.4	88.2	79.9	71.7
11		93.3	85.4	78
12		97.9	90.1	83.1
13			94.3	87.5
14			98.2	91.5
15				95.1
16				98.4

Sample Point Number	% Along Traverse			
	n=18	n=20	n=22	n=24
1	1.4	1.3	1.1	1.1
2	4.4	3.9	3.5	3.2
3	7.5	6.7	6	5.5
4	10.9	9.7	8.7	7.9
5	14.6	12.9	11.6	10.5
6	18.8	16.5	14.6	13.2
7	23.6	20.4	18	16.1
8	29.6	25	21.8	19.4
9	38.2	30.6	26.2	23
10	61.8	38.8	31.5	27.2
11	70.4	61.2	39.3	32.3
12	76.4	69.4	60.7	39.8
13	81.2	75	68.5	60.2
14	85.4	79.6	73.8	67.7
15	89.1	83.5	78.2	72.8
16	92.5	87.1	82	77
17	95.6	90.3	85.4	80.6
18	98.6	93.3	88.4	83.9
19		96.1	91.3	86.8
20		98.7	94	89.5
21			96.5	92.1
22			98.9	94.5
23				96.8
24				98.9

PRELIMINARY TRAVERSE DATA RECORDING SHEET (CIRCULAR DUCTS)

Site Reference	GM-1002818
Site Name	ALAN NUTRIS.
Stack Reference	SPRAY BOOTH
Date	06/04/15
Time	10:42
Staff	AW/HB

Stack Diameter	0.80	m
Static pressure	0	mmH ₂ O
Barometric pressure	100.7	mbar
Pitot Cp	0.8404	
Oxygen	-	%
Moisture	-	%

Stagnation Pressure Check (S Type Pitot)

(Difference between Leg A and B must be < 10Pa or < 1mmH₂O)

Leg A	7	Pa
Leg B	5	Pa

ΔP units	Pa	or	mmH ₂ O
----------	----	----	--------------------

Velocity Traverse

Traverse Point	Traverse % Line A	Depth cm	ΔP,1	ΔP,2	ΔP,3	ΔP,ave	T,1 °C	T,2 °C	T,3 °C	T,ave °C	Angle °
1	2.1	5.0	55	55	57	55.7	14	14	14	14	0
2	6.7	8.4	35	37	36	36.0	14	14	14	14	0
3	11.8	15.0	33	31	32	32.0	14	14	14	14	0
4	17.7	21.8	27	29	30	28.7	14	14	14	14	0
5	25	28.5	20	22	22	21.3	14	14	14	14	0
6	35.6	55.2	12	13	13	12.7	14	14	14	14	0
7	64.4	41.9	11	14	13	12.7	14	14	14	14	0
8	75	68.6	8	9	10	9.0	14	14	14	14	0
9	82.3	55.3	5	6	8	6.3	14	14	14	14	0
10	88.2	61.96	6	7	7	6.7	14	14	14	14	0
11	93.3	68.6	5	7	6	6.0	14	14	14	14	0
12	97.9	75.0	7	8	8	7.7	14	14	14	14	0
Point	Line B	Depth	ΔP,1	ΔP,2	ΔP,3	ΔP,ave	T,1	T,2	T,3	T,ave	Angle
1	2.1										
2	6.7										
3	11.8										
4	17.7										
5	25										
6	35.6										
7	64.4										
8	75										
9	82.3										
10	88.2										
11	93.3										
12	97.9										

An electronic manometer was used to provide a direct reading of average differential pressure over at least 1 minute

Sampling plane requirements Re: BS EN 13284-1:2001 5.2

Angle of gas flow less than 15° with regard to duct axis	✓
No local negative flow	✓
Minimum pitot greater than 5Pa	✓
Minimum local gas velocity	2.6
Maximum local gas velocity	7.9
Ratio of highest to lowest local gas velocity	3.05

Pitot	104
Manometer	P803
Temperature ind.	126
Thermocouple	145
Barometer	36.1
Timer	705

BS EN 13284-1:2002 Sampling Points

Range of Sampling plain areas (m ²)	Range of Duct Diameters (m)	Minimum Number of Sampling lines (diameters)	Minimum Number of Sampling Points per plane
<0.1	0.35		1a
0.1 to 1.0	0.35 to 1.1	2	4
1.1 to 2.0	1.1 to 1.6	2	8
>2.0	>1.6	2	At least 12 and 4 per m ^{2b}

^a Using only one sampling point may give rise to errors greater than those specified in the method and the standard

^b For Large ducts, a number of 20 sampling points is generally sufficient.

Tangential Rule Sampling Points

Sample Point Number	% Along Traverse			
	n=2	n=4	n=6	n=8
1	14.6	6.7	4.4	3.3
2	85.4	25	14.6	10.5
3		75	29.6	19.4
4		93.3	70.4	32.3
5			85.4	67.7
6			95.6	80.6
7				89.5
8				96.7

Sample Point Number	% Along Traverse			
	n=10	n=12	n=14	n=16
1	2.6	2.1	1.8	1.6
2	8.2	6.7	5.7	4.9
3	14.6	11.8	9.9	8.5
4	22.6	17.7	14.6	12.5
5	34.2	25	20.1	16.9
6	65.8	35.6	26.9	22
7	77.4	64.4	36.6	28.3
8	85.4	75	63.4	37.5
9	91.8	82.3	73.1	62.5
10	97.4	88.2	79.9	71.7
11		93.3	85.4	78
12		97.9	90.1	83.1
13			94.3	87.5
14			98.2	91.5
15				95.1
16				98.4

Sample Point Number	% Along Traverse			
	n=18	n=20	n=22	n=24
1	1.4	1.3	1.1	1.1
2	4.4	3.9	3.5	3.2
3	7.5	6.7	6	5.5
4	10.9	9.7	8.7	7.9
5	14.6	12.9	11.6	10.5
6	18.8	16.5	14.6	13.2
7	23.6	20.4	18	16.1
8	29.6	25	21.8	19.4
9	38.2	30.6	26.2	23
10	61.8	38.8	31.5	27.2
11	70.4	61.2	39.3	32.3
12	76.4	69.4	60.7	39.8
13	81.2	75	68.5	60.2
14	85.4	79.6	73.8	67.7
15	89.1	83.5	78.2	72.8
16	92.5	87.1	82	77
17	95.6	90.3	85.4	80.6
18	98.6	93.3	88.4	83.9
19		96.1	91.3	86.8
20		98.7	94	89.5
21			96.5	92.1
22			98.9	94.5
23				96.8
24				98.9

APPENDIX 4
RANHEAT BOILER & WET
SPRAY BOOTH

PRELIMINARY GAS
MEASUREMENTS & WATER
VAPOUR RESULTS

APPENDIX 4.1

PRELIMINARY MOISTURE RESULTS

10:15 - 10:55
(29/05/14)

11:54 - 12:34
(30/05/14)

Sampling Data	Ranheat Boiler	Wet Spray Booth
Run Time (min)	40	40
Total mass H ₂ O collected (g)	27.6	7.6
Pitot tube constant, Cp	0.85	0.85
Dry gas meter (DGM) volume (m ³)	0.766	1.059
Temperature DGM (°C)	17	22
Temperature stack (°C)	143	31
Mean pitot tube pressure drop, delta P (mm H ₂ O)	8.5	2.4
Orifice meter pressure drop, delta H (mm H ₂ O)	34.3	54.6
Barometric Pressure (kPa)	98.9	99.9
X-sectional area of stack (m ²)	0.038	0.503
Nozzle size (mm)	7.01	10.09
Flow Data		
Velocity, actual (m/s)	12.2	5.5
Velocity, ntp (m/s)	7.9	4.9
Vol. Flow, actual (m ³ /hr)	1,664	9,871
Vol. Flow, ntp (m ³ /hr)	1,078	8,803
Volume sampled, ntp, dry gas (m ³)	0.691	0.963
Volume sampled, ntp, wet gas (m ³)	0.726	0.973
Emission Data		
H ₂ O (% vol)	4.7	1.0

APPENDIX 4.2

PRELIMINARY GAS MEASUREMENT RESULTS

Stack Ref	H ₂ O	O ₂	CO		Total VOCs	
	(%vol)	(%vol)	ppm	mg/m ³	ppm	mg/m ³ (as C)
Ranheat Boiler	4.7	16.5	93.1	111.0	2.9	4.6
Uncertainty (±)	0.2	0.4		13.8		1.7

APPENDIX 5

RANHEAT BOILER

GAS ANALYSER CALIBRATION MEASUREMENTS

GAS SAMPLING WORKBOOK

GAS CALIBRATION CYLINDERS USED				Job No: 02818
Cylinder No	Contents	Concentration	Uncertainty	Client Site: Nuttab
VC8177253	N ₂	99.99%	10/1A	Date: 09/4/15
VCSMG5960	CO	156.4 ppm	1.008%	Sampling Team: AW/HB
VCSMG5960	O ₂	12.03%	1.0%	
VC10044	Zero Air	0	1.100%	
VCDY0207	C ₃ H ₈	9.9 ppm	2%	

GAS REGULATOR CHECKLIST	
H ₂ /He	AQ
Acid Gas	AQ
Other Gas	AQ RRG38 RRG83
Other:	AQ

Task	✓	X	Comments
Regulator has AQ No	✓		
Check Gauge Covers and Condition	✓		
Suitable pressure range for work in hand	✓		
Inlet in good condition	✓		
Outlet in good condition	✓		
Leak check head on cylinder	✓		
Gauge reads zero OK	✓		
Gauge reads pressure OK	✓		
Pass/Fail	P		
Checked by	AW/rme		
Date	9/4/15		

INSTRUMENT INFORMATION

Site	Alon Nuttall					
Job Number	02818					
Date	9/4/15					
Equipment Details:-	AQ:	NO _x	CO	O ₂	SO ₂	CO ₂
Horiba	268	-	-	-	-	-
Range	-	-	0-200	0-25	-	-
Repeatability at Zero	-	0.43	4.5	0.06	0.06	-
Repeatability at Span	-	-	0.32	0.84	-	-
	AQ:	VOC	Comments			
FID	270	-				
Range	-	0-10				
Repeatability at Zero	-	0.1				
Repeatability at Span	-	0.05				
	AQ:	Comments				
Heated Line	315					
Heated Line Controller	316					
Heated Line						
Heated Line Controller						
Data Logger	Time logger					
Data Logger						

PRE-CALIBRATION CHECKS

Parameter:	NOx VOCs	SO ₂	CO	O ₂ (dry)
Instrument:	40.1hr AQ 341			
Instrument:	62.1hr AQ 270			
Atmospheric Pressure (kPa):	101.3			
Ambient Temperature °C:	23.5			
Gas Conditioning Unit <4°C	Yes/No			

NOTE: Instrument Span/Zero = back of instrument, System Span/Zero = end of line to allow leakage to be assessed

Pre Sampling Cal	Span/Zero Gas Ref	Gas Conc.	Time	T ₉₀ Value	Response Time T ₉₀	Instrument Reading	Comment - (eg. zero deviation <2% the repeatability at zero, system span <2% and zero <2% span gas value)
Instrument Zero	N ₂	0	8.15			0	Set to span zero
Instrument Span	CO	156.4	8.21			156.4	Set to span
Instrument Zero Re-Check	N ₂	0	8.27			0	< 2% repeatability
System Zero	N ₂	0	9.00			0	< 2% span
System Span	CO	156.4	9.05	120.8	27	156.3	< 2% span
Instrument Zero	N ₂	0	8.15			0	Set to zero
Instrument Span	O ₂	12.03	8.21			12.03	Set to span
Instrument Zero Re-Check	N ₂	0	8.27			0	< 2% repeatability
System Zero	N ₂	0	9.00			0.01	< 2% span
System Span	O ₂	12.03	9.05	13.2	25	12.04	< 2% span

PRE-CALIBRATION CHECKS

Parameter:	NOx VOCs	SO ₂	CO	O ₂ (dry)	Job No: 02818
Instrument: <i>here</i>	AQ				Client Site: <i>Ac ny Hdg</i>
Instrument: FID	AQ 270				Date: 4/4/15
Atmospheric Pressure (kPa): 100.0					Data Saved as
Ambient Temperature °C:					FID: See Page 3
Gas Conditioning Unit <4°C	Yes / No				Horiba: See Page 3

NOTE: Instrument Span/Zero = back of instrument, System Span/Zero = end of line to allow leakage to be assessed

Pre Sampling Cal	Span/Zero Gas Ref	Gas Conc.	Time	T ₉₀ Value	Response Time T ₉₀	Instrument Reading	Comment - (eg. zero deviation <2 X the repeatability at zero, system span <2% and zero <2% span gas value)
Instrument Zero	<i>NOx 200</i> <i>1/4 2 Air</i>	0	8.33			0	<i>adjusted to zero</i>
Instrument Span	C ₃ H ₈	9.9	8.38			9.9	<i>adjusted to SGV.</i>
Instrument Zero Re-Check	Zero Air	0	8.43			0	<i>< 2x repeatability at zero</i>
System Zero	<i>9/4 3Haw</i> <i>200 Air</i>	0	8.49			0	<i>< 2% SGV</i>
System Span	C ₃ H ₈	9.9	8.55	<i>8.91</i> <i>23</i>	23	9.9	<i>< 2% SGV</i>
Instrument Zero							
Instrument Span							
Instrument Zero Re-Check							
System Zero							
System Span							

POST CALIBRATION CHECKS

Parameter:	NO _x VOCs	SO ₂	CO	O ₂ (dry)	CO ₂	Job No: 02818
Instrument:	341 AQ Horizon					Client Site: Alan White
Instrument:	270 AQ Burner					Date: 6/6/15
Atmospheric Pressure (kPa):	101.3					Data Saved as
Ambient Temperature °C:	23.2					FID: See Page 3
						Horiba: See Page 3

Post Sampling Cal	Span/Zero Gas Ref	Gas Conc.	Time	Response Time T ₉₀ (from Pre-Cal)	Instrument Reading	Comment - (eg. drift >2% - no correction, >2% -5% - correction applied or >5% measurement rejection)
Zero	N ₂	0	14:39.3		0.12	< 2% 56V
Span	O ₂	12.03	14:40	25	12.02	< 2% 56V
Zero	N ₂	0	14:33		0.6	< 2% 56V
Span	CO	156.4	14:40	27	153.7	< 2% 56V
Zero	Zero Air	0	14:44		0.02	< 2% 56V
Span	C3H8	9.9	14:47	23	9.92	< 2% 56V
Zero						
Span						
Zero						
Span						
Zero						
Span						

APPENDIX 6
RANHEAT BOILER

GAS ANALYSER RESULTS

APPENDIX 6.1

COMBUSTION GAS EMISSION DATA SUMMARY

Stack Ref	H ₂ O	O ₂	CO	
	(%vol)	(%vol)	ppm	mg/m ³
Ranheat Boiler	4.2	13.5	45.4	54.4
Uncertainty (±)	0.1	0.4	-	2.2

APPENDIX 6.2

TOTAL VOC EMISSION DATA SUMMARY

Stack Ref	Total VOCs	
	ppm (as C ₃ H ₈)	mg/m ³ as C
Ranheat Boiler	7.7	12.3
Uncertainty (±)	-	1.7

Fig 1: Combustion Gas Emission Data, Alan Nuttall Ltd, Ranheat Boiler, (09/04/15)





Fig 2: Total VOC Emission Data, Alan Nuttall Ltd, Ranheat Boiler, (09/04/15)



APPENDIX 7
RANHEAT BOILER & WET
SPRAY BOOTH

LABORATORY CERTIFICATES OF
ANALYSIS

Scientific Analysis Laboratories Ltd

Certificate of Analysis

Hadfield House
Hadfield Street
Cornbrook
Manchester
M16 9FE
Tel : 0161 874 2400
Fax : 0161 874 2404

Scientific Analysis Laboratories is a
limited company registered in England and
Wales (No 2514788) whose address is at
Hadfield House, Hadfield Street, Manchester M16 9FE

Report Number: 469275-1

Date of Report: 17-Apr-2015

Customer: REC Environmental Monitoring Ltd
10 Broad Lane
Moldgreen
Huddersfield
HD5 9BX

Customer Contact: The Emissions Group

Customer Job Reference: EM 1p02818

Date Job Received at SAL: 10-Apr-2015

Date Analysis Started: 14-Apr-2015

Date Analysis Completed: 17-Apr-2015

The results reported relate to samples received in the laboratory
Opinions and interpretations expressed herein are outside the scope of UKAS accreditation
This report should not be reproduced except in full without the written approval of the laboratory
Tests covered by this certificate were conducted in accordance with SAL SOPs
All results have been reviewed in accordance with QP22



Report checked
and authorised by :
Michael Goodman
Project Management

Issued by :
Kayleigh McCann
Project Manager

Signature valid

Digitally signed by Kayleigh
McCann
Date: 2015.04.17 16:44:14 BST
Reason: Issue
Location: SAL

SAL Reference: 469275 Customer Reference: EM 1p02818 Impinger(DI water) Analysed as Impinger(DI water) Miscellaneous							
SAL Reference		469275 007		469275 010		469275 011	
Customer Sample Reference		EM-1p02818/7		EM-1p02818/10		EM-1p02818/11	
Test Sample		AR		AR		AR	
Date Sampled		09-APR-2015		09-APR-2015		09-APR-2015	
Determinand	Method	LOD	Units	Symbol			
Hydrogen Chloride	IC	0.05	mg/l	U	(13) 1.1	(195,13) 79	(13) 1.3
Volume	Vol	1	ml	U	110	260	160

SAL Reference: 469275 Customer Reference: EM 1p02818 Impinger (sodium hydroxide) Analysed as Impinger (sodium hydroxide) Miscellaneous							
SAL Reference		469275 012		469275 013			
Customer Sample Reference		EM-1p02818/12		EM-1p02818/13			
Test Sample		AR		AR			
Date Sampled		09-APR-2015		09-APR-2015			
Determinand	Method	LOD	Units	Symbol			
Hydrogen Cyanide	Colorimetry	0.05	mg/l	N	<0.05	<0.05	
Volume	Vol	1	ml	N	170	520	

SAL Reference: 469275 Customer Reference: EM 1p02818 Wash(Acetone) Analysed as Wash(Acetone) Miscellaneous							
SAL Reference		469275 001		469275 003		469275 005	
Customer Sample Reference		EM-1p02818/1		EM-1p02818/3		EM-1p02818/5	
Test Sample		AR		AR		AR	
Date Sampled		08-APR-2015		08-APR-2015		09-APR-2015	
Determinand	Method	LOD	Units	Symbol			
Particulates (Total)	Grav	0.3	mg	U	0.4	2.8	0.6
							9.6

SAL Reference: 469275 Customer Reference: EM 1p02818 Filter GFA 110mm Analysed as Filter GFA 110mm Miscellaneous							
SAL Reference		469275 002		469275 004			
Customer Sample Reference		EM-1p02818/2		EM-1p02818/4			
Test Sample		AR		AR			
Date Sampled		08-APR-2015		08-APR-2015			
Determinand	Method	LOD	Units	Symbol			
Particulates (Total)	Grav (5 Dec)	0.10	mg	U	0.92	4.8	

SAL Reference: 469275 Customer Reference: EM 1p02818 Filter Quartz 85mm Analysed as Filter Quartz 85mm Miscellaneous							
SAL Reference		469275 006		469275 009			
Customer Sample Reference		EM-1p02818/6		EM-1p02818/9			
Test Sample		AR		AR			
Date Sampled		09-APR-2015		09-APR-2015			
Determinand	Method	LOD	Units	Symbol			
Particulates (Total)	Grav (5 Dec)	0.10	mg	U	<0.10	64	

Index to symbols used in 469275-1

Value	Description
AR	As Received
195	Due to levels found in the sample that are outside of the normal calibration range of the instrument, analysis was conducted on a diluted sample
13	Results have been blank corrected.
U	Analysis is UKAS accredited
N	Analysis is not UKAS accredited



Test Certificate

Date 22/04/2015

Client	REC Ltd Unit 19 Bordesley Trading Estate Bordesley Green Rd Birmingham B8 1BZ	Order No.	0250 EM
		Certificate No.	WK15-2001
		Issue No.	1
Contact	Mr Derek Myers	Date Received	15/04/2015
Description	3 samples for formaldehyde in water	Technique	Wet Chemistry

Sample No.	832192	EM-1p02818/14	Method
Formaldehyde	<0.1 µg/ml	174 ml	M103(U)
Sample No.	832193	EM-1p02818/15	Method
Formaldehyde	<0.1 µg/ml	326 ml	M103(U)
Sample No.	832194	EM-1p02818/16	Method
Formaldehyde	<0.1 µg/ml	168 ml	M103(U)



Test Certificate

Date 22/04/2015

Client	REC Ltd	Certificate No.	WK15-2001
		Issue No.	1

Tested By	Ashley Lunt	Date	22/04/2015
-----------	-------------	------	------------

Approved By		Date	22/04/2015
-------------	---	------	------------

Lora McKerracher
Chemist

For and on authority of RPS Laboratories Ltd.

Method Symbols (U) Analysis is UKAS Accredited
 (N) Analysis is not UKAS Accredited

Concentration values (mg/m³ and ppm) are calculated on the basis of information provided by the customer.
Results stated as ml are referring to the sample volume.

RPS Laboratories terms and conditions apply - a copy is available on request.

Analysis carried out on samples 'as received'

This document may not be reproduced other than in full, except with the written approval of the issuing laboratory.

APPENDIX 8
RANHEAT BOILER & WET
SPRAY BOOTH

MANUAL MONITORING RESULTS

APPENDIX 8.1

PARTICULATE EMISSION DATA SUMMARY- WET SPRAY BOOTH

DATE: 08/04/15

11:14 - 11:54

Sampling Data	
Run Time (min)	40
Total mass H ₂ O collected (g)	3.9
Pitot tube constant, C _p	0.82
Dry gas meter (DGM) volume (m ³)	0.849
Temperature DGM (°C)	17
Temperature stack (°C)	23
Mean pitot tube pressure drop, delta P (mm H ₂ O)	2.7
Orifice meter pressure drop, delta H (mm H ₂ O)	45.5
Barometric Pressure (kPa)	100.7
X-sectional area of stack (m ²)	0.503
Nozzle size (mm)	8.98
Flow Data	
Velocity, actual (m/s)	5.5
Velocity, ntp (m/s)	5.1
Vol. Flow, actual (m ³ /hr)	10,003
Vol. Flow, ntp (m ³ /hr)	9,199
Volume sampled, ntp, dry gas (m ³)	0.770
Volume sampled, ntp, wet gas (m ³)	0.775
Analytical Data	
Filter Weight Gain (mg)	4.8
Acetone Wash Residue Weight (mg)	2.8
Total Particulates (mg)	7.6
Partics Field Blank (mg)	1.3
Blank % of ELV	0.9
Emission Data	
H ₂ O (% vol)	0.6
Percentage Isokinetic	100.4
Particulates (mg/m ³)	9.8
Uncertainty (± mg/m ³)	1.4
Uncertainty (%ELV)	0.7

APPENDIX 8.2

PARTICULATE & HCl EMISSION DATA SUMMARY RANHEAT BOILER

DATE: 09/04/15

12:35 - 13:05

Sampling Data	
Run Time (min)	30
Total mass H ₂ O collected (g)	27.7
Pitot tube constant, C _p	0.82
Dry gas meter (DGM) volume (m ³)	0.881
Temperature DGM (°C)	25
Temperature stack (°C)	131
Mean pitot tube pressure drop, delta P (mm H ₂ O)	7.2
Orifice meter pressure drop, delta H (mm H ₂ O)	80.6
Barometric Pressure (kPa)	101.3
X-sectional area of stack (m ²)	0.038
Nozzle size (mm)	8.98
Flow Data	
Velocity, actual (m/s)	10.6
Velocity, ntp (m/s)	7.1
Vol. Flow, actual (m ³ /hr)	1,448
Vol. Flow, ntp (m ³ /hr)	978
Volume sampled, ntp, dry gas (m ³)	0.784
Volume sampled, ntp, wet gas (m ³)	0.818
Analytical Data	
Filter Weight Gain (mg)	64.0
Acetone Wash Residue Weight (mg)	9.6
Total Particulates (mg)	73.6
Partics Field Blank (mg)	0.6
Blank % of ELV	0.3
Mass HCl (ug)	20748
HCl Field Blank (mg/l)	1.10
Absorber Efficiency (%HCl in Impingers 1+2)	99.0
Emission Data	
H ₂ O (% vol)	4.2
Percentage Isokinetic	100.5
Particulates (mg/m ³)	89.9
Uncertainty (± mg/m ³)	3.8
Uncertainty (%ELV)	1.9
HCl (mg/m ³)	25.4
Uncertainty (± mg/m ³)	3.1
Uncertainty (%ELV)	3.1

APPENDIX 8.3

FORMALDEHYDE EMISSION DATA SUMMARY

DATE: 09/04/15

13:46 - 14:16

Sampling Data	
Run Time (min)	30
Total mass H ₂ O collected (g)	23.5
Pitot tube constant, C _p	0.82
Dry gas meter (DGM) volume (m ³)	0.810
Temperature DGM (°C)	29
Temperature stack (°C)	133
Mean pitot tube pressure drop, delta P (mm H ₂ O)	6.6
Orifice meter pressure drop, delta H (mm H ₂ O)	74.2
Barometric Pressure (kPa)	101.3
X-sectional area of stack (m ²)	0.038
Nozzle size (mm)	8.98
Flow Data	
Velocity, actual (m/s)	10.2
Velocity, ntp (m/s)	6.8
Vol. Flow, actual (m ³ /hr)	1,391
Vol. Flow, ntp (m ³ /hr)	936
Volume sampled, ntp, dry gas (m ³)	0.710
Volume sampled, ntp, wet gas (m ³)	0.739
Analytical Data	
Mass HCHO Imp 1+2 (ug)	<49.4
HCHO Field Blank (mg/l)	<0.1
Absorber Efficiency (%HCHO in Impinger 1)	66.0
Emission Data	
H ₂ O (% vol)	4.0
Percentage Isokinetic	94.9
HCHO (mg/m ³)	<0.067
Uncertainty (± mg/m ³)	<0.010

APPENDIX 8.4

HCN EMISSION DATA SUMMARY

Sampling Data	Ranheat Boiler
Start Time/Date	13:31, 09/04/15
End Time/Date	14:41, 09/04/15
Sampling Period (min)	40
DGM start (dry m ³)	52.229
DGM end (dry m ³)	52.295
Volume Sampled (dry m ³)	0.066
Ambient Temp (°C)	23.5
Ambient Press (kPa)	100
Wt of Water (g)	3.8
Volume Water (m ³)	0.005
Volume Sampled, 273K, 101.3kPa (dry m ³)	0.060
Volume Sampled, 273K, 101.3kPa (wet m ³)	0.065
Volume NaOH Impinger 1+ 2 (ml)	520
Analytical Data	
HCN Blank (mg/l)	<0.05
HCN in NaOH Imp1+2(mg/l)	<0.05
total HCN (µg)	26
Emission Concentration Data	
Moisture (%vol)	7.3
HCN (mg/m ³)	<0.40



Resource & Environmental Consultants Ltd

ISOKINETIC SAMPLING WORKBOOK

Site	ALAN NUTRALS	
Stack	SPRAY BOOTH	
Job Number	GM-1802818	
Date	08/04/15	
Sampling Team	HB/AW	
Equipment Used:-	MUST enter AQ numbers below	
Nozzle(s)	AQ	153
Probe(s)		14
Pitot(s)	AQ	104
Timer	AQ	308
Glassware Set		Brewer Set 1
Thermocouple(s)	AQ	145
Temperature Indicator	AQ	126
Control Console	AQ	126
Digital Manometer	AQ	PD03
Tape Measure	AQ	268
Balance	AQ	070

14/12/15

Workbook checked by:	M. Eames
----------------------	----------

This workbook should only be reproduced in full except with written approval from REC Ltd
Any opinions or interpretations are outside the laboratory's UKAS schedule of accreditation

IMPORTANT!!!
ANY CROSSINGS OUT SHOULD BE MADE USING A SINGLE LINE AND INITIALLED
ALL SECTIONS TO BE COMPLETED AND SIGNED WHERE APPROPRIATE

[illegible]

DIAGRAMS OF STACK

Plan of site layout including approx dimensions	Schematic diagram of the stack inc dimensions
	<p>Stack Dimensions = cm (diameter) x cm (traverse 1st)</p> <p style="text-align: center;">Ø 0.80 -</p>

Other Notes

LEAKAGE RATES FOR CONSOLE DRY GAS METERS

Leakage to be less than 2% of maximum nominal flowrate of meter

AQ140		2% leak l/min	
mm H ₂ O	l/min	5	8.1
5		8.1	0.16
10		9.8	0.20
15		12.3	0.25
20		14.1	0.28
25		16.0	0.32
30		17.4	0.35
35		18.8	0.38
40		19.6	0.39
45		21.4	0.43
50		22.2	0.44
55		23.7	0.47
60		24.5	0.49
65		25.5	0.51
70		27.0	0.54
75		27.8	0.56
80		28.8	0.58
85		29.6	0.59
90		30.4	0.61
95		31.2	0.62
100		32.2	0.64
110		33.8	0.68
120		35.2	0.70
130		36.7	0.73
140		37.8	0.76

AQ126		2% leak l/min	
mm H ₂ O	l/min	5	7.3
5		7.3	0.15
10		10.5	0.21
15		12.7	0.25
20		14.7	0.29
25		16.5	0.33
30		17.9	0.36
35		19.5	0.39
40		20.8	0.42
45		22.0	0.44
50		23.5	0.47
55		24.6	0.49
60		26.0	0.52
65		26.9	0.54
70		27.8	0.56
75		28.9	0.58
80		29.8	0.60
85		30.8	0.62
90		31.7	0.63
95		32.4	0.65
100		33.4	0.67
110		35.2	0.70
120		36.6	0.73
130		38.2	0.76
140		39.6	0.79

AQ002		2% leak l/min	
mm H ₂ O	l/min	5	7.7
5		7.7	0.15
10		10.3	0.21
15		12.6	0.25
20		14.2	0.28
25		16.4	0.31
30		16.4	0.33
35		17.9	0.36
40		18.9	0.38
45		20.1	0.40
50		21.2	0.42
55		22.1	0.44
60		23.2	0.46
65		24.1	0.48
70		24.9	0.50
75		25.7	0.51
80		26.5	0.53
85		27.1	0.54
90		27.9	0.56
95		28.7	0.57
100		29.5	0.59
110		30.9	0.62
120		32.1	0.64
130		33.1	0.66
140		34.5	0.69

AQ003		2% leak l/min	
mm H ₂ O	l/min	5	7.5
5		7.5	0.15
10		10.1	0.20
15		12.3	0.25
20		13.9	0.28
25		15.1	0.30
30		16.1	0.32
35		17.6	0.35
40		18.6	0.37
45		19.7	0.39
50		20.9	0.42
55		21.8	0.44
60		22.9	0.46
65		23.7	0.47
70		24.5	0.49
75		25.3	0.51
80		26.1	0.52
85		26.7	0.53
90		27.5	0.55
95		28.3	0.57
100		29.1	0.58
110		30.5	0.61
120		31.7	0.63
130		32.7	0.65
140		34.1	0.68

AQ325		2% leak l/min	
mm H ₂ O	l/min	5	8.2
5		8.2	0.16
10		11.6	0.23
15		13.8	0.28
20		15.1	0.30
25		16.8	0.34
30		18.1	0.36
35		19.3	0.39
40		20.9	0.42
45		22.0	0.44
50		23.3	0.47
55		24.4	0.49
60		25.8	0.52
65		26.4	0.53
70		27.0	0.54
75		28.2	0.56
80		29.4	0.59
85		30.2	0.60
90		30.8	0.62
95		31.7	0.63
100		32.0	0.64
110		34.9	0.70
120		35.0	0.70
130		36.7	0.73
140		38.2	0.76

AQ326		2% leak l/min	
mm H ₂ O	l/min	5	8.0
5		8.0	0.16
10		11.0	0.22
15		13.2	0.26
20		15.0	0.30
25		16.5	0.33
30		17.9	0.36
35		19.1	0.38
40		20.5	0.41
45		21.7	0.43
50		23.0	0.46
55		24.2	0.48
60		25.1	0.50
65		26.1	0.52
70		26.5	0.53
75		27.9	0.56
80		28.5	0.57
85		29.4	0.59
90		30.0	0.60
95		30.9	0.62
100		31.9	0.64
110		33.8	0.68
120		34.6	0.69
130		35.9	0.72
140		37.2	0.74

Site:	ALAN NUTRALS.		MOISTURE	Contents	Start Weight (g)	End Weight (g)	Gain (g)	
Stack Description:	SPRAY BOOTH.		Impinger 1	D.H ₂ O.	599.2	590.4	-8.8	
Test No:	PARTIC		Impinger 2	D.H ₂ O.	669.9	673.3	3.4	
Date:	08/04/15.		Impinger 3	BLK	666.1	667.4	1.3	
Filter No:	489.		Impinger 4	S.G.	807.8	815.8	8.0	
Site Team:	AW/HB		Impinger 5				3.9	
Start time	11:14.	hr:min	Impinger 6					
End time	11:54	hr:min	Impinger 7					
total time sampled	40	hr:min	Leak Check (see leakage rate conversions mmH ₂ O to l/min and 2% l/min values)					
Nozzle diameter:	8.997	mm	Max nominal flowrate - (from preliminary pitot traverse)	32.4	l/min	Sampling flowrate - (from volume sampled/time)	28	l/min
K Factor:	16.84.		2% of max nominal flowrate - (from preliminary pitot traverse)	0.65	l/min	2% of sampling flowrate - (from volume sampled/time)	0.57	l/min
Stack Pres (with +/- above barometric if unknown enter zero)	0	mm H ₂ O	Actual pre-test leak check result + Vac Gauge Reading	0.4	l/min	Actual post-test leak check result + Vac Gauge Reading	0.2	l/min
Reference Standard (E.g BS EN 13284, USEPA M26a etc.)	BS EN 13284		COMMENTS: (E.g. Deviations from the Methods)					
Does test conform to standard (Y/N)	Y							
Start volume reading	4.6002	m ³						
End volume reading	5.4494	m ³						
Barometric Pressure	100.7	kPa						
Reference O ₂	N/A	%						
Ambient Temp	14.	°C						

16.84

16.84.

	Time Hr : Min	Sample Point	Time at each position min	ΔP mm H ₂ O	ΔH mm H ₂ O	Stack Temp °C	Probe Temp °C	Meter In °C	Meter Out °C	Oven Temp °C	Exit Temp °C	Cond. Temp °C	Vac. in Hg
1:	01:14	A1	5	5.0	84.2	15	160	15	15	160	12	—	-3.5
2:	19			5.0	84.2	17	160	16	16	160	14	—	-4.0
3:	24	A2		3.0	50.5	23	160	17	17	160	15	—	-3.0
4:	29			3.0	50.5	24	160	18	17	160	15	—	-3.0
5:	34	A3		1.8	30.3	26	160	18	18	160	16	—	-2.0
6:	39			1.8	30.3	25	160	18	18	160	16	—	-2.0
7:	44	A4		1.0	16.8	27	160	19	19	160	16	—	-1.0
8:	49			1.0	16.8	27	160	19	19	160	17	—	-1.0
9:	54	End											
10:													
11:													
12:													
13:													
14:													
15:													
16:													
17:													
18:													
19:													
20:													
21:													
22:													
23:													
24:													
25:													
26:													
27:													
Average values													

ISOKINETIC SAMPLING WORKBOOK

Site	ALAN NUTTALS	
Stack	Boiler	
Job Number	GM-1P02818	
Date	09/04/15	
Sampling Team	AW/AB	
Equipment Used:-	MUST enter AQ numbers below	
Nozzle(s)	AQ	153
Probe(s)		14
Pitot(s)	AQ	104
Timer	AQ	308
Glassware Set		Bham Set 1
Thermocouple(s)	AQ	142
Temperature Indicator	AQ	126
Control Console	AQ	126
Digital Manometer	AQ	126
Tape Measure	AQ	268
Balance	AQ	070

Workbook checked by:	M Edwards
----------------------	-----------

This workbook should only be reproduced in full except with written approval from REC Ltd
Any opinions or interpretations are outside the laboratory's UKAS schedule of accreditation

IMPORTANT!!!
ANY CROSSINGS OUT SHOULD BE MADE USING A SINGLE LINE AND INITIALLED
ALL SECTIONS TO BE COMPLETED AND SIGNED WHERE APPROPRIATE

SITE NOTES & BLANK(S) DETAILS - Please use this page to record site details, problems on site re access, non conforming work etc, pitot and DGM leak check results. For blank(s) details, include stack ref, substance, time taken, etc.

BSW13254. blank completed. 9/4/15

BSW1411

USEPA M316 - blank completed 9/4/15

DIAGRAMS OF STACK

Plan of site layout including approx dimensions	Schematic diagram of the stack inc dimensions
	<p data-bbox="807 512 1401 575">Stack Dimensions = cm (diameter) x cm (traverse 1st)</p> <p data-bbox="1027 595 1240 645"><i>Ø 22cm .</i></p>

Other Notes

LEAKAGE RATES FOR CONSOLE DRY GAS METERS

Leakage to be less than 2% of maximum nominal flowrate of meter

AQ140		
mm H ₂ O	l/min	2% leak l/min
5	8.1	0.16
10	9.8	0.20
15	12.3	0.25
20	14.1	0.28
25	16.0	0.32
30	17.4	0.35
35	18.8	0.38
40	19.6	0.39
45	21.4	0.43
50	22.2	0.44
55	23.7	0.47
60	24.5	0.49
65	25.5	0.51
70	27.0	0.54
75	27.8	0.56
80	28.8	0.58
85	29.6	0.59
90	30.4	0.61
95	31.2	0.62
100	32.2	0.64
110	33.8	0.68
120	35.2	0.70
130	36.7	0.73
140	37.8	0.76

AQ126		
mm H ₂ O	l/min	2% leak l/min
5	7.3	0.15
10	10.5	0.21
15	12.7	0.25
20	14.7	0.29
25	16.5	0.33
30	17.9	0.36
35	19.5	0.39
40	20.8	0.42
45	22.0	0.44
50	23.5	0.47
55	24.6	0.49
60	26.0	0.52
65	26.9	0.54
70	27.8	0.56
75	28.9	0.58
80	29.8	0.60
85	30.8	0.62
90	31.7	0.63
95	32.4	0.65
100	33.4	0.67
110	35.2	0.70
120	36.6	0.73
130	38.2	0.76
140	39.6	0.79

AQ002		
mm H ₂ O	l/min	2% leak l/min
5	7.7	0.15
10	10.3	0.21
15	12.6	0.25
20	14.2	0.28
25	15.4	0.31
30	16.4	0.33
35	17.9	0.36
40	18.9	0.38
45	20.1	0.40
50	21.2	0.42
55	22.1	0.44
60	23.2	0.46
65	24.1	0.48
70	24.9	0.50
75	25.7	0.51
80	26.5	0.53
85	27.1	0.54
90	27.9	0.56
95	28.7	0.57
100	29.5	0.59
110	30.9	0.62
120	32.1	0.64
130	33.1	0.66
140	34.5	0.68

AQ003		
mm H ₂ O	l/min	2% leak l/min
5	7.5	0.15
10	10.1	0.20
15	12.3	0.25
20	13.9	0.28
25	15.1	0.30
30	16.1	0.32
35	17.6	0.35
40	18.6	0.37
45	19.7	0.39
50	20.9	0.42
55	21.8	0.44
60	22.9	0.46
65	23.7	0.47
70	24.5	0.49
75	25.3	0.51
80	26.1	0.52
85	26.7	0.53
90	27.5	0.55
95	28.3	0.57
100	29.1	0.58
110	30.5	0.61
120	31.7	0.63
130	32.7	0.65
140	34.1	0.68

AQ325		
mm H ₂ O	l/min	2% leak l/min
5	8.2	0.16
10	11.6	0.23
15	13.8	0.28
20	15.1	0.30
25	16.3	0.34
30	18.1	0.36
35	19.3	0.39
40	20.9	0.42
45	22.0	0.44
50	23.3	0.47
55	24.4	0.49
60	25.8	0.52
65	26.4	0.53
70	27.0	0.54
75	28.2	0.56
80	29.4	0.59
85	30.2	0.60
90	30.8	0.62
95	31.7	0.63
100	32.0	0.64
110	34.9	0.70
120	36.0	0.70
130	36.7	0.73
140	38.2	0.76

AQ326		
mm H ₂ O	l/min	2% leak l/min
5	3.0	0.16
10	11.0	0.22
15	13.2	0.26
20	15.0	0.30
25	16.5	0.33
30	17.9	0.36
35	19.1	0.38
40	20.5	0.41
45	21.7	0.43
50	23.0	0.46
55	24.2	0.48
60	25.1	0.50
65	26.1	0.52
70	26.5	0.53
75	27.9	0.56
80	28.5	0.57
85	29.4	0.59
90	30.0	0.60
95	30.9	0.62
100	31.9	0.64
110	33.8	0.66
120	34.6	0.69
130	35.9	0.72
140	37.2	0.74

Site:	ALAN NATALS		MOISTURE	Contents	Start Weight (g)	End Weight (g)	Gain (g)
Stack Description:	WOOD BURNER BOILER		Impinger 1	D ₁ H ₂ O	644.6 682.7 HB	648.1	3.5
Test No:	PARTIC/HC		Impinger 2	D ₁ H ₂ O	660.4 594.4 HB	670.1	9.7
Date:	09/04/15		Impinger 3	D ₁ H ₂ O	682.1 729.5 HB	733.4	3.9
Filter No:	334 492 HB		Impinger 4	Bik	666.4 573.1 HB	573.2	0.1
Site Team:	AW/HB		Impinger 5	S.G.	878.5	888.7	10.2
Start time	12:35	hr:min	Impinger 6				
End time	13:05	hr:min	Impinger 7				
total time sampled	00:30	hr:min	Leak Check (see leakage rate conversions mmH ₂ O to l/min and 2% l/min values)				
Nozzle diameter:	8.9 7 87	mm	Max nominal flowrate - (from preliminary pitot traverse)	25	l/min	Sampling flowrate - (from volume sampled/time)	29.4 l/min
K Factor:	11.24		2% of max nominal flowrate - (from preliminary pitot traverse)	0.56	l/min	2% of sampling flowrate - (from volume sampled/time)	0.58 l/min
Stack Pres (with +/- above barometric if unknown enter zero)	-2.7	mm H2O	Actual pre-test leak check result + Vac Gauge Reading	0.2	l/min	Actual post-test leak check result + Vac Gauge Reading	0.2 -18
Reference Standard (E.g BS EN 13284, USEPA M26a etc.)	BS EN 13284 BS EN 9117		COMMENTS: (E.g. Deviations from the Methods)				
Does test conform to standard (Y/N)	Y						
Start volume reading	6.9671 3.0214	m ³					
End volume reading	3.9024	m ³					
Barometric Pressure	100.3	kPa					
Reference O ₂	—	%					
Ambient Temp	14	°C					

17.24

	Time Hr : Min	Sample Point	Time at each position min	ΔP mm H ₂ O	ΔH mm H ₂ O	Stack Temp °C	Probe Temp °C	Meter In °C	Meter Out °C	Oven Temp °C	Exit Temp °C	Cond. Temp °C	Vac. In Hg
1:	12:35	C.P.	S	8.0	89.9	130	160	27	21	160	14		-1.0
2:	40			7.0	78.7	130	160	28	17	160	14		-1.0
3:	45			7.0	78.7	130	160	29	19	160	15		-1.0
4:	50			7.0	78.7	131	160	30	21	160	16		-2.0
5:	55			7.0	78.7	132	160	30	22	160	17		-2.0
6:	13:00			7.0	78.7	134	160	31	24	160	17		-2.5
7:	13:05	END V											
8:													
9:													
10:													
11:													
12:													
13:													
14:													
15:													
16:													
17:													
18:													
19:													
20:													
21:													
22:													
23:													
24:													
25:													
26:													
27:													
Average values													

Site:	ALAN NUTRALS		MOISTURE	Contents	Start Weight (g)	End Weight (g)	Gain (g)
Stack Description:	Boiler		Impinger 1	D ₁ H ₂ O	651.3	656.8	5.5
Test No:	FORMALDEHYDE		Impinger 2	D ₁ H ₂ O	688.1	695.9	7.8
Date:	09/04/15		Impinger 3	D ₁ H ₂ O	744.9	747.9	3.0
Filter No:	N/A		Impinger 4	BLK	573.3	574.3	1.0
Site Team:	AW/HB		Impinger 5	S.G.	888.7	894.9	6.2
Start time	13:46	hr:min	Impinger 6				
End time	14:16	hr:min	Impinger 7				
total time sampled	00:30	hr:min	Leak Check (see leakage rate conversions mmH ₂ O to l/min and 2% l/min values)				
Nozzle diameter:	8.99	mm	Max nominal flowrate - (from preliminary pitot traverse)	25.9	l/min	Sampling flowrate - (from volume sampled/time)	26.97 l/min
K Factor:	11.24		2% of max nominal flowrate - (from preliminary pitot traverse)	0.52	l/min	2% of sampling flowrate - (from volume sampled/time)	0.54 l/min
Stack Pres (with +/- above barometric if unknown enter zero)	-22	mm H2O	Actual pre-test leak check result + Vac Gauge Reading	0.4	l/min	Actual post-test leak check result + Vac Gauge Reading	0.2 l/min
Reference Standard (E.g BS EN 13284, USEPA M26a etc.)	USEPA M316		COMMENTS: (E.g. Deviations from the Methods)				
Does test conform to standard (Y/N)	Y						
Start volume reading	39176	m ³					
End volume reading	47274	m ³					
Barometric Pressure	101.3	kPa					
Reference O ₂	—	%					
Ambient Temp	16	°C					

	Time Hr : Min	Sample Point	Time at each position min	ΔP mm H ₂ O	ΔH mm H ₂ O	Stack Temp °C	Probe Temp °C	Meter In °C	Meter Out °C	Oven Temp °C	Exit Temp °C	Cond. Temp °C	Vac. in Hg
1:	13:46	C.P.		7	78.7	132	120	27	26	120	14		-1.0
2:	51			7	78.7	133	120	33	27	120	14		-1.0
3:	56			7	78.7	131	120	33	27	120	14		-1.0
4:	14:01			7	78.7	133	120	33	28	120	15		-2.0
5:	6.			7	78.7	134	120	32	28	120	16		-4.5
6:	11			4.6	51.7	134	120	31	28	120	17		-7.5
7:	16		C.N.A.										
8:													
9:													
10:													
11:													
12:													
13:													
14:													
15:													
16:													
17:													
18:													
19:													
20:													
21:													
22:													
23:													
24:													
25:													
26:													
27:													
Average values													

NON-ISOKINETIC AND MOISTURE SAMPLING WORKSHEET

Client: A. Nuttal
 Job No.: 02818
 Date: 9/4/15
 Sampling Operator: AW/HB
 Test: HCN
 Checked by/ Date: ME/ 11/5/15

Sampling Location: Wood burning boiler outlet
 Pump Ref AQ: ~~33~~ 199
 DGM Ref AQ: ~~191~~ 33 199
 Balance Ref AQ: 90
 T/C + Reader AQ: 301 / 163

Start Leak Check: 0.0 L/min
 End Leak Check: 0.0 L/min
 Start Time: 13:31
 End Time: 14:11
 DGM Start (m³): 52, 229
 DGM Start Temp (°C): 23
 DGM End (m³): 52.2948
 DGM End Temp (°C): 24.
 Period Sampled (min): 40
 Barometric Pressure (kPa): 100.8^{mm}

Impinger Ref	Contents	Start Weight (g)	End Weight (g)	Weight Gain (g)
1	0.1m NaOH	636.7	637.4	0.7
2	0.1m NaOH	752.4	753.6	1.2
3	Empty	395.1	395.7	0.6
4	Silica gel	640.2	641.5	1.3
Total Gain (g)				3.8

APPENDIX 9
RANHEAT BOILER & WET
SPRAY BOOTH

UNCERTAINTY CALCULATIONS

Uncertainty calculation for EN 13284 Determination of low range mass concentration of dust, Manual Gravimetric Method

Spreadsheet completed by:
Date:

ME
11/5/15

Checked by:
Date:

DM
11/5/15

Measurement Equation

$$c = \frac{m}{V} f_c$$

Limit value	200	mg.m ⁻³	Reference oxygen	21.0	% by volume
Measured concentration	9.80	mg.m ⁻³			

Measured Quantities	Symbol	Value	Standard uncertainty	Units	Uncertainty as percentage	Uncertainty at lv	Requirement of std
Sampled Volume	V _m	0.849	uV _m	0.001	m ³	0.12	<=2%
Sampled gas Temperature	T _m	290.4375	uT _m	2	K	0.69	<=1%
Sampled gas Pressure	p _m	100.7	up _m	1	kPa	0.99	<=1%
Sampled gas Humidity	H _m	0.626303678	uH _m	1	% by volume	159.67	<=1%
Oxygen content	O _{2,m}	21.0	uO _{2,m}	0.1	% by volume	0.48	<=5%
Mass particulate	m	7.6	um	0.522015325	mg	6.87	0.34 <5% of limit value
Note - Sampled gas humidity, temperature and pressure are values at the gas meter							
Leak	L	2		%	2.00		<=2%
Uncollected Mass (Instack filter - no rinse)	UCM	0		mg	0		<=10%

Intermediate calculations

Factor for std conds	fs	0.929				
uncertainty components	symbol	sensitivity coeff	u (in units of fs)			
	p _m	0.009	0.009			
	H _m	0.009	0.009			
	T _m	0.003	0.006			
	ufs		0.015			1.57
Corrected volume	V	0.789	uV	0.012	m ³	1.58
$V = V_m f_s$						
Factor for O2 correction	fc	1.00				
uncertainty components	symbol	sensitivity coeff	u			
	O _{2,m}	1.00	0.100			
$f_c = \frac{21 - O_{2,ref}}{21 - O_{2,m}}$						
Factor for O2 Correction	ufc	1.00		0.100		10.00

Parameter	Uncertainty, Value	Units	Sensitivity coeff	Uncertainty in Result	Uncertainty as %
Volume(standard conditions)	V	0.789 m ³	12.43	0.15 mg.m ⁻³	1.58 %
Mass	m	7.60 mg	1.29	0.67 mg.m ⁻³	6.87
Factor for O2 Correction	fc	1.00	0.00	0.00 mg.m ⁻³	0.00 %
Leak	L	0.11 mg.m ⁻³	1.00	0.11 mg.m ⁻³	
Uncollected mass	UCM	0.00 mg	1.29	0.00 mg.m ⁻³	
Combined uncertainty				0.70 mg.m ⁻³	

Expanded uncertainty	expressed with a level of confidence of 95%	14.28 %
Expanded uncertainty	expressed with a level of confidence of 95%	1.40 mg.m ⁻³
Expanded uncertainty as percentage of limit value		0.7 % of ELV

Uncertainty calculation for HCl Impingement Method

rec
Date: 11/5/15

ME
11/5/15

Checked by:
Date: 11/5/15

DM
11/5/15

Limit value	100	mg.m ⁻³	Reference oxygen	21	% by volume
Measured concentration	25.35	mg.m ⁻³			

Measurement Equation

$c = \frac{m}{V} f_c$

Measured Quantities	Symbol	Value	Standard uncertainty	Units	Uncertainty as percentage	Uncertainty at h Requirement of std
Sampled Volume	V _m	0.881	uV _m	0.001 m ³	0.11	<=2%
Sampled gas Temperature	T _m	297.916667	uT _m	2 k	0.67	<=1%
Sampled gas Pressure	p _m	101.3	up _m	1 kPa	0.99	<=1%
Sampled gas Humidity	H _m	4.21	uH _m	1 % by volume	23.73	<=1%
Oxygen content	O _{2,m}	21	uO _{2,m}	0.1 % by volume	0.48	<=5%
Mass HCl	m	20748	um	1209.81 ug	5.83	1.48 <5% of limit value
Note - Sampled gas humidity, temperature and pressure are values at the gas meter						
Leak	L	2		%	2.00	<=2%
Uncollected Mass	UCM	0		mg	0	<=10%
Impinger Weight	Iw	1.3		%	1.3	<=5%

Intermediate calculations				
Factor for std conds	fs	0.88		
uncertainty components	symbol	sensitivity coeff	u (in units of fs)	
	p _m	0.009	0.009	
	H _m	0.009	0.009	$f_s = \frac{(100 - H_m) 273}{100 T_m 101.3} \rho_m$
	T _m	0.003	0.006	
	ufs		0.014	1.59
Corrected volume	V	0.818	uV	0.012 m ³ V = V _m f _s 1.50
Factor for O2 correction	fc	1.00		
uncertainty components	symbol	sensitivity coeff	u	$f_c = \frac{21 - O_{2,ref}}{21 - O_{2,m}}$
	O _{2,m}	1.00	0.100	
Factor for O2 Correction	ufc	1.00	0.100	10.00

Parameter	Uncertainty Value	Units	Sensitivity coef	Uncertainty in Result	Uncertainty as %
Volume(standard conditions)	V	0.818 m ³	30.98	0.38 mg.m ⁻³	1.50 %
Mass HCl	m	20748.00 ug	1.00	1.48 mg.m ⁻³	5.83 %
Factor for O2 Correction	fc	1.00	0.00	0.00 mg.m ⁻³	0.00 %
Leak	L	0.29 mg.m ⁻³	1.00	0.29 mg.m ⁻³	
Uncollected mass	UCM	0.00 mg	1.00	0.00 mg.m ⁻³	
Impinger weight	I	0.19 mg.m ⁻³	1.00	0.19 mg.m ⁻³	
Combined uncertainty				1.57 mg.m ⁻³	

Expanded uncertainty	expressed with a level of confidence of 95%	12.35 %
Expanded uncertainty	expressed with a level of confidence of 95%	3.13 mg.m ⁻³
Expanded uncertainty as percentage of limit value		3.1 % of ELV

Chloride Analysis Uncertainty

HCl Uncertainty	4.00 %
Volume Uncertainty	1 %
Uncertainty of HCl ug Calc	5.83 %

Uncertainty calculation for HCl Impingement Method

rec	ME	Checked by:	DM
Date:	11/5/15	Date:	11/5/15
Limit value	100 mg.m ⁻³	Reference oxygen	21 % by volume
Measured concentration	25.35 mg.m ⁻³		

Measurement Equation

$$c = \frac{m}{V} f_c$$

Measured Quantities	Symbol	Value	Standard uncertainty	Units	Uncertainty as percentage	Uncertainty at lv	Requirement of std
Sampled Volume	V _m	0.881	uV _m	0.001 m ³	0.11		<=2%
Sampled gas Temperature	T _m	297.916667	uT _m	2 k	0.67		<=1%
Sampled gas Pressure	p _m	101.3	uρ _m	1 kPa	0.99		<=1%
Sampled gas Humidity	H _m	4.21	uH _m	1 % by volume	23.73		<=1%
Oxygen content	O _{2,m}	21	uO _{2,m}	0.1 % by volume	0.48		<=5%
Mass HCl	m	20748	um	1209.81 ug	5.83	1.48	<5% of limit value
Note - Sampled gas humidity, temperature and pressure are values at the gas meter							
Leak	L	2		%	2.00		<=2%
Uncollected Mass	UCM	0		mg	0		<=10%
Impinger Weight	Iw	1.3		%	1.3		<=5%

Intermediate calculations					
Factor for std conds	fs	0.88			
uncertainty components	symbol	sensitivity coeff	u (in units of fs)		
	ρ _m	0.009	0.009		
	H _m	0.009	0.009		
	T _m	0.003	0.006		
	ufs		0.014		1.59
Corrected volume	V	0.818	uV	0.012 m ³	V = V _m f _s 1.50
Factor for O2 correction	fc	1.00			
uncertainty components	symbol	sensitivity coeff	u		
	O _{2,m}	1.00	0.100		
Factor for O2 Correction	ufc	1.00	0.100		10.00

Parameter	Uncertainty, Value	Units	Sensitivity coeff	Uncertainty in Result	Uncertainty as %
Volume(standard conditions)	V	0.818 m ³	30.98	0.38 mg.m ⁻³	1.50 %
Mass HCl	m	20748.00 ug	1.00	1.48 mg.m ⁻³	5.83 %
Factor for O2 Correction	fc	1.00	0.00	0.00 mg.m ⁻³	0.00 %
Leak	L	0.29 mg.m ⁻³	1.00	0.29 mg.m ⁻³	
Uncollected mass	UCM	0.00 mg	1.00	0.00 mg.m ⁻³	
Impinger weight	I	0.19 mg.m ⁻³	1.00	0.19 mg.m ⁻³	
Combined uncertainty				1.57 mg.m ⁻³	

Expanded uncertainty	expressed with a level of confidence of 95%	12.35 %
Expanded uncertainty	expressed with a level of confidence of 95%	3.13 mg.m ⁻³
Expanded uncertainty as percentage of limit value		3.1 % of ELV

Chloride Analysis Uncertainty

HCl Uncertainty	4.00 %
Volume Uncertainty	1 %
Uncertainty of HCl ug Calc	5.83 %

Uncertainty calculation for EN 13284 Determination of low range mass concentration of dust, Manual Gravimetric Method

Spreadsheet completed by:
Date:

ME
11/5/15

Checked by:
Date:

DM
11/5/15

Measurement Equation

$$c = \frac{m}{V} f_c$$

Limit value	200	mg.m ⁻³	Reference oxygen	21.0	% by volume
Measured concentration	89.93	mg.m ⁻³			

Measured Quantities	Symbol	Value	Standard uncertainty	Units	Uncertainty as percentage	Uncertainty at lv	Requirement of std
Sampled Volume	V _m	0.881	uV _m	0.001	m ³	0.11	<=2%
Sampled gas Temperature	T _m	297.9166667	uT _m	2	K	0.67	<=1%
Sampled gas Pressure	ρ _m	101.3	uρ _m	1	kPa	0.99	<=1%
Sampled gas Humidity	H _m	4.214301132	uH _m	1	% by volume	23.73	<=1%
Oxygen content	O _{2,m}	21.0	uO _{2,m}	0.1	% by volume	0.48	<=5%
Mass particulate	m	73.6	um	0.522015325	mg	0.71	0.32 <5% of limit value
Note - Sampled gas humidity, temperature and pressure are values at the gas meter							
Leak	L	2		%	2.00		<=2%
Uncollected Mass (Instack filter - no rinse)	UCM	0		mg	0		<=10%

Intermediate calculations

Factor for std conds	fs	0.878				
uncertainty components	symbol	sensitivity coeff	u (in units of fs)			
	ρ _m	0.009	0.009			
	H _m	0.009	0.009			
	T _m	0.003	0.006			
	ufs		0.014			1.59
Corrected volume	V	0.773	uV	0.012	m ³	1.59
$V = V_m f_s$						
Factor for O2 correction	fc	1.00				
uncertainty components	symbol	sensitivity coeff	u			
	O _{2,m}	1.00	0.100			
$f_c = \frac{21 - O_{2,ref}}{21 - O_{2,m}}$						
Factor for O2 Correction	ufc	1.00		0.100		10.00

Parameter	Uncertainty, Value	Units	Sensitivity coeff	Uncertainty in Result	Uncertainty as %
Volume(standard conditions)	V	0.773 m ³	116.30	1.43 mg.m ⁻³	1.59 %
Mass	m	73.60 mg	1.22	0.64 mg.m ⁻³	0.71 %
Factor for O2 Correction	fc	1.00	0.00	0.00 mg.m ⁻³	0.00 %
Leak	L	1.04 mg.m ⁻³	1.00	1.04 mg.m ⁻³	
Uncollected mass	UCM	0.00 mg	1.22	0.00 mg.m ⁻³	
Combined uncertainty				1.88 mg.m ⁻³	

Expanded uncertainty	expressed with a level of confidence of 95%	4.18 %
Expanded uncertainty	expressed with a level of confidence of 95%	3.76 mg.m ⁻³
Expanded uncertainty as percentage of limit value		1.9 % of ELV

Uncertainty calculation for Gaseous Measurement - VOCs

Completed by	ME	11/5/15	Wood Burning Boiler	EM-02818
Checked by	DM	11/5/15	9/4/15	Alan Nuttal Ltd
Limit value	100	mg.m ⁻³ (corrected) CO	Gas	Propane CH3
Measured concentration	7.66	ppm dry	Full Scale	10
Measured concentration	12.31	mg.m ⁻³ (273K, 101.3kPa) CO	Cal gas conc	10
			Conversion	1.607142857
			Full Scale	16.07142857
			Cal gas conc	15.91071429
				mg.m ⁻³ (CO)
				mg.m ⁻³ (CO)

Correction for reference conditions				
		O2, %	Moisture, %	Pressure, KPa
	ref	21.00		101.30
	measured	21.00		101.30
Factors		1.00	1.00	1.00
Correction Factor		1.09		

Performance characteristics	Value		specification
Response time	23	seconds	180.000
Number of readings in measurement	61		
Repeatability at zero	0.1	% full scale	0.200
Repeatability at span level	0.1	% full scale	2.000
Deviation from linearity	1.0	% of value	2.000
Zero drift	0.2	% full scale	2.000
Span drift	0.2	% full scale	2.000
volume or pressure flow dependence	1.0	% of reading/10hPa	0.033
atmospheric pressure dependence	0.5	% of value/10hPa	0.750
ambient temperature dependence	2.0	% full scale/10K	0.300
NH3 (20 mg/m3)		mg/m3	
CO2 (15%)		% by vol	
H2O (30%)		% by vol	4.000
dependence on voltage	1.0	% full scale/10V	2%/fs/10V
losses in the line (leak)	1.5	% of value	2% of value
Uncertainty of calibration gas	2.0	% of value	

Effect of drift
0.06 mg/m3
0.46 % value

	ranges		
	min	max	value at calib
flow	0.3	0.5	0.4
pressure	101.30	101.5	101.3
temp	283	289	283
NH3 range	0	0	0
CO2 range	0	0.5	0
H2O range	0	0.5	0
Instrument Voltage Rating			110
Voltage	104.5	115.5	110

Measurement performance related to stationary conditions					
Performance characteristic		Uncertainty		Value of uncertainty quantity	
Standard deviation of repeatability at zero		U _{r0}		for mean	use rep at span
Standard deviation of repeatability at span level		U _{rs}		for mean	0.01
Lack of fit		U _{flt}			0.09
Drift		U _{odr}			0.03
volume or pressure flow dependence		U _{spres}			0.00
atmospheric pressure dependence		U _{apres}			0.01
ambient temperature dependence		U _{temp}			0.69
NH3 (20 mg/m3)		U _{interf}			0.00
CO2 (15%)					0.00
H2O (30%)					0.00
Dependence on voltage		U _{volt}			0.32
losses in the line (leak)		U _{leak}			0.11
Uncertainty of calibration gas		U _{calib}			0.14

Measurement uncertainty		Result	12.31	mg/m ³
Combined uncertainty			0.79	mg/m ³
Expanded uncertainty	k =	2	1.58	mg/m ³
Uncertainty corrected to std conds			1.71	mg.m-3 (corrected)
Expanded uncertainty	expressed with a level of confidence of 95%		1.71	% ELV
Expanded uncertainty	expressed with a level of confidence of 95%		1.71	mg.m ⁻³ at ELV

Use largest negative or positive interferent effect	
0	0.00
0	0.00
0	0.00
0	0.00
Interference uncertainty	0.00

Uncertainty calculation for HCHO, DNPH Impingement Method

Spreadsheet completed by:
Date:

ME
11/5/15

Checked by:
Date:

DM
11/5/15

Measurement Equation

$$c = \frac{m}{V} f_c$$

Limit value	5 mg.m ⁻³	Reference oxygen	21 % by volume
Measured concentration	0.07 mg.m ⁻³		

Measured Quantities	Symbol	Value	Standard uncertainty	Units	Uncertainty as percentage	Uncertainty at lv	Requirement of std
Sampled Volume	V _m	0.8098	uV _m	0.001 m ³	0.12		<=2%
Sampled gas Temperature	T _m	302.4166667	uT _m	2 k	0.66		<=1%
Sampled gas Pressure	ρ _m	101.3	uρ _m	1 kPa	0.99		<=1%
Sampled gas Humidity	H _m	3.96	uH _m	1 % by volume	25.26		<=1%
Oxygen content	O _{2,m}	21	uO _{2,m}	0.1 % by volume	0.48		<=5%
Mass HCHO	m	49	um	3.55 ug	7.19	0.10	<5% of limit value
Note - Sampled gas humidity, temperature and pressure are values at the gas meter							
Leak	L	2		%	2.00		<=2%
Uncollected Mass	UCM	0		mg	0		<=10%
Impinger Weight	Iw	1.3		%	1.3		<=5%

Intermediate calculations

Factor for std conds	fs	0.87				
uncertainty components	symbol	sensitivity coeff	u (in units of fs)			
	ρ _m	0.009	0.009			
	H _m	0.009	0.009			
	T _m	0.003	0.006			
	ufs		0.014			1.58
Corrected volume	V	0.739	uV	0.011 m ³	$V = V_m f_s$	1.51
Factor for O2 correction	fc	1.00				
uncertainty components	symbol	sensitivity coeff	u			
	O _{2,m}	1.00	0.100		$f_c = \frac{21 - O_{2,ref}}{21 - O_{2,m}}$	
Factor for O2 Correction	ufc	1.00	0.100			10.00

Parameter	Uncertainty, Value	Units	Sensitivity coeff	Uncertainty in Result	Uncertainty as %
Volume(standard conditions)	V	0.739 m ³	0.09	0.00 mg.m ⁻³	1.51 %
Mass HCHO	m	49.40 ug	1.00	0.00 mg.m ⁻³	7.19 %
Factor for O2 Correction	fc	1.00	0.00	0.00 mg.m ⁻³	0.00 %
Leak	L	0.00 mg.m ⁻³	1.00	0.00 mg.m ⁻³	
Uncollected mass	UCM	0.00 mg	1.00	0.00 mg.m ⁻³	
Impinger weight	I	0.00 mg.m ⁻³	1.00	0.00 mg.m ⁻³	
Combined uncertainty				0.00 mg.m ⁻³	

Expanded uncertainty expressed with a level of confidence of 95% 14.94%

Expanded uncertainty expressed with a level of confidence of 95% 0.01 mg.m⁻³

HCHO Analysis Uncertainty

HCHO mean	0.5017 mg/l (nominal 0.5 mg/l)
HCHO sd	0.0125 mg/l
HCHO Uncertainty	4.98 %
Volume Uncertainty	1 %
Uncertainty of HCHO ug Calc	7.19 %