




Client Staffordshire Crystal Ltd.
 Unit 14 Pedmore Road Ind. Estate
 Brierly Hill
 West Midlands
 DY5 1TJ

Part 1: Executive Summary

Report for the Periodic Monitoring of Emissions to Air.

Site	Brierly Hill
Plant	Wet Arrestor
Sampling Date	14th October 2014
Report Date	25th November 2014
Job Number	2p71962
Permit Number	PB/98 Variation 200839393

Report Prepared by:	Print	Graham Rowley
	MCERTS No.	MM 03 148 Level 2 TE: 1,2,3,4

Report Approved by:	Sign	
	Print	Emily Buffam
	MCERTS No.	MM 04 502 Level 2 TE: 1,2,3,4

REC Environmental Monitoring Ltd
 10 Broad Lane
 Moldgreen
 Huddersfield
 HD5 9BX

Tel: 0845 676 9303
 Company Registration No 08343822



Contents

Page 1	Part 1: Executive Summary
Page 2	Contents
Page 3	Monitoring Objectives
Page 3	Special Monitoring Requirements
Page 4	Summary Of Methods
Page 4	Summary Of Results
Page 5	Operating Information
Page 5	Comments On Monitoring Procedures
Page 6	Part 2: Supporting Information
Page 7	Appendix 1
Page 8	Emission Monitoring Procedures and Instrumentation
Page 9	Sampling Personnel
Page 9	Equipment References
Page 9	Subcontracted Analysis
Page 10	Appendix 2
Page 11	Preliminary Velocity Traverse & Moisture Data
Page 12	Total Particulate Matter - Sampling Data
Page 13	Total Particulate Matter - Emission Results
Page 14	Lead - Sampling Data
Page 15	Lead - Emission Result
Page 16	Lead - Field Blank Emission Result
Page 17	Appendix 3
Page 18	Diagram of Sampling Location
Page 19	Generic Calculations
Page 20	Flow Calculations
Page 21	Concentration Calculation
Page 22	Uncertainty Estimate Calculations - Manual Techniques
Page 23	Appendix 4
Page 24	Uncertainty Estimates:- Total Particulate Matter
Page 25	Uncertainty Estimates:- Lead

Monitoring Objectives

The monitoring was undertaken to check compliance with authorised emission limits.

All monitoring procedures were carried out to the MCERTS requirements under the REC Environmental Monitoring quality system to ISO 17025: 2005.

Monitoring was undertaken for the listed emissions from the following sampling positions:

Sampling Location	Emission
Wet Arrestor	Particulates Lead

Special Monitoring Requirements

There were no special requirements for this monitoring campaign.

Summary Of Methods

Emission	Method number	Method standard
Particulate	TPM/04	BS EN 13284 - 1 : 2002
Gas velocity	TPM/01	BS EN 13284 : 2002
Water vapour	TPM/37	BS EN 14790 : 2005
Lead	TPM/06b	BS EN 14385 : 2004

Summary Of Results

The table presents the atmospheric emissions from the tests undertaken on behalf of **Staffordshire Crystal Ltd.** The results were measured from the sample positions downstream of the arrestment plant.

Emission at Brierly Hill Wet Arrestor	Sampling Time			Emission Result mg/m ³ *	Authorised Limit mg/m ³ *	Uncertainty +/- mg/m ³ *	Detection Limit mg/m ³ *	Mass Emission g/h
	Date	Start	End					
Particulate	14/10/14	15:24	16:04	1.09	20	0.26	0.71	5.18
s Lead	14/10/14	14:28	15:08	0.009	5	0.003	0.001	0.044

* at reference conditions	Stack Gas Weight	0 °C	Without correction for moisture
	29.00 Kg/kmol	101.3 kPa	Oxygen No Correction %

Where applicable Oxides of nitrogen results are expressed as nitrogen dioxide
TOC results are expressed as total carbon

Throughout Report: * Reference conditions (see above) Nm³ 273 K, 101.3 kPa
** Analysis not required # - UKAS accredited only
ND Non detectable ## - Not Accredited
s - Subcontracted laboratory analysis N/A Not applicable

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor k=2, providing a 95% confidence level. The uncertainty evaluation has been carried out in accordance with UKAS requirements.



All tests included in this report are accredited under UKAS and MCERTS accreditation schemes unless otherwise stated. Opinions and interpretations expressed herein are outside the scope of MCERTS and UKAS accreditation.



Operating Information

The tables below shows details of the operating information on each sampling date for: **Wet Arrestor**

Date	Process type	Process duration	Fuel	Feedstock	Abatement	Load
14/10/2014	Process Extraction	Continuous	-	Glass	Water Trough	Normal operation

There are no CEMs currently installed on this process for the determinands being monitored.

Comments & Monitoring Deviations

A waste gas homogeneity test to BS EN 15259:2007 (MID) is not required:-
The homogeneity test is not applicable to non-combustion processes.
The homogeneity test is not applicable to duct areas less than 1m².

All monitoring was performed in accordance with the relevant procedures.

Sampling could only be undertaken from the one port available and of limited points as a result of insufficient platform size and restricted access.

The particulate monitoring was within the required 95 to 115 % isokinetic rate as stated in BS EN 13284-1: 2002

The velocity and temperature profile at the sampling location met the requirements of BS EN 13284-1: 2002.

The impinger efficiency check for lead was not performed because the measured emission was less than 30% of the emission limit value.

When the results are expressed as non-detected the mass emissions are calculated from the detection limit and therefore they are worst case results.




Part 2: Supporting Information

Report for the Periodic Monitoring of Emissions to Air.

Client	Staffordshire Crystal Ltd.
Site	Brierly Hill
Plant	Wet Arrestor
Sampling Date	14th October 2014
Report Date	25th November 2014
Job Number	2p71962
Permit Number	PB/98 Variation 200839393

Report Prepared by:	Print	Graham Rowley	
	MCERTS No.	MM 03 148	Level 2 TE: 1,2,3,4

Report Approved by:	Sign		
	Print	Emily Buffam	
	MCERTS No.	MM 04 502	Level 2 TE: 1,2,3,4

REC Environmental Monitoring Ltd
10 Broad Lane
Moldgreen
Huddersfield
HD5 9BX

Tel: 0845 676 9303
Company Registration No 08343822



APPENDIX 1

Emission Monitoring Procedures And Instrumentation

Gas velocity and temperature

Documented in-house procedure TPM/01 to the main procedural requirements of BS EN 13284:2002. Velocity and temperature measurements are performed using a calibrated Pitot tube, as described in BS ISO 10780:1994 and a calibrated thermocouple. Velocity and possible flow deviation measurements are carried out at selected, representative points in the gas stream.

Water vapour

Documented in-house procedure TPM/37 to the main procedural requirements of BS EN 14790:2005. A measured volume of gas is extracted from the gas stream through a moisture trapping unit. The mass gain of moisture trapped is divided by the volume of gas sampled to determine the mass concentration of water vapour. For water saturated stacks the temperature of the gas stream is measured and the water vapour concentration is determined using liquid-gas equilibrium tables. Sampling points are selected in accordance with the findings of any BS EN 15259 assessment.

Total particulate matter

Documented in-house procedure TPM/04 to the main procedural requirements of BS EN 13284-1:2002. Stack gases are extracted from representative sampling points at isokinetic flow rates through a sharp-edged nozzle. Particulate matter is collected on a pre-weighed filter conditioned at 180°C. Deposits upstream of the filter are also recovered and weighed. The increase of mass of the filter and mass collected upstream of the filter is divided by the volume sampled to determine the mass concentration.

Lead

Documented in-house procedure TPM/06b to the main procedural requirements of BS EN 14385:2004 - substantial metered volume of gas sampled isokinetically through a sharp edged nozzle dedicated heated probe, filter, and chilled impinger train containing appropriate hydrogen peroxide/nitric acid and sulphuric acid/potassium permanganate solutions, and subsequent Inductively Coupled Plasma Optical Emission Spectrometry (ICP-OES) analysis.

Sampling Project Personnel Competency And Expiry Dates

		MCERTS No	Level 1	Level 2	TE1	TE2	TE3	TE4
Report prepared by:	Graham Rowley	MM 03 148	-	30/11/2018	30/11/2018	31/03/2015	31/10/2019	31/03/2020
Report authorised by:	Emily Buffam	MM 04 502	-	30/06/2016	30/06/2016	31/08/2016	31/08/2016	31/08/2016
Team leader:	Graham Rowley	MM 03 148	-	30/11/2018	30/11/2018	31/03/2015	31/10/2019	31/03/2020
Technician:	Tom Clarkson	MM 02 120	31/12/2018	-	-	-	-	-

Equipment References

Equipment	Reference Number
Probe	P48
Probe Thermocouple	TP48
Stack Thermocouple	TS48
Control Box	CU13
Timer / Stopwatch	CU13/8
Barometer	WS04
Pitot	PT113
Callipers	CV17
Hot Box	HB23
Impinger Thermocouple	TV34
Sample Rate Calculation Equipment	Laptop
Balance	BL19
Weights	W35, W36

Subcontracted Analysis

REC Environmental Monitoring has, with your approval, used the following sub-contracted laboratories for the laboratory analyses referenced below:

Laboratory:	Scientific Analysis Laboratories
Parameters:	Heavy Metals - Internal method ICPMS BS EN 14385
Accreditation:	UKAS Accredited testing laboratory number 1549

APPENDIX 2

Date	14/10/2014
Time	13:30
Pitot Cp	0.85

Barometric pressure	98.9	kPa
Duct static pressure	-0.02	kPa
Stack Area	0.302	m ²

Stack Diameter (circular)	0.62	m
---------------------------	------	---

Traverse Point	Traverse Line	Depth cm	ΔP mmH ₂ O	T °C	Angle °	velocity m/s	Traverse Line	Depth cm	ΔP mmH ₂ O	T °C	Angle °	velocity m/s
1	A	5.0	2.0	16	<15	4.9	B	5.0			<15	
2	A	5.0	2.0	16	<15	4.9	B	5.0			<15	
3	A	7.3	1.5	16	<15	4.2	B	7.3			<15	
4	A	11.0	2.0	16	<15	4.9	B	11.0			<15	
5	A	15.5	2.5	16	<15	5.5	B	15.5			<15	
6	A	22.1	2.5	16	<15	5.5	B	22.1			<15	
7	A	39.9	2.0	16	<15	4.9	B	39.9			<15	
8	A	46.5	3.0	16	<15	6.0	B	46.5			<15	
9	A	51.0	2.5	16	<15	5.5	B	51.0			<15	
10	A	54.7	3.0	16	<15	6.0	B	54.7			<15	
11	A	57.0	4.0	16	<15	6.9	B	57.0			<15	
12	A	57.0	2.5	16	<15	5.5	B	57.0			<15	

Average Pitot DP	2.42	mmH ₂ O
Average Temperature	289.2	K
Average Velocity	5.4	m/s
Average volumetric flow rate	1.62	m ³ /s at stack conditions
Average volumetric flow rate	1.49	m ³ /s (wet STP)

Sampling plane requirements Re: BS EN 13284-1:2001 5.2

a	Angle of gas flow less than 15° with regard to duct axis	YES
b	No local negative flow	YES
c	Minimum pitot greater than 5Pa	YES
d	Ratio of highest to lowest local gas velocity less than 3:1	YES
	Minimum local gas velocity	4.2
	Maximum local gas velocity	6.9
	Ratio of highest to lowest local gas velocity	1.63

Moisture Determination BS EN 14790:2005

	Volume m ³	Temp °C	Pressure mbar
Meter start	5.470	14	989
Meter end	6.188	16	989
Meter Yd	1.002		
Gas volume	0.666		

Impinger	1	2	3	4	5
Mass start (g)	679.9	726.3	754.6	583.3	947.5
Mass End (g)	680.0	728.6	755.5	584.0	951.5
Total Mass collected (g)	8.0				
Water vapour content (% v/v)	1.5				

If water droplets are present in the gas, the water vapour content is calculated using BS EN 14790 Annex A

N/A % v/v

Preliminary Velocity Traverse & Moisture Data

Probe/Pitot ID No	P48/PT113	Nozzle Diameter (d)	mm	9.07
Pitot Calibration Factor (Cp)	0.85	In-stack Filtration	Y/N	N
Gas Calibration Factor (Y)	1.002	Leak check OK	Y/N	Y
Barometric Pressure	kPa 98.9	Meter ID No		CU13
Duct static Pressure	kPa -0.02	Initial Gas Meter Reading	m ³	6.402
Date	14/10/2014	Final Gas Meter Reading	m ³	7.144
Start Time	hh:min 15:24	Sampled Vol, Dry at Meter	m ³	0.742
End Time	hh:min 16:04	Sampled Vol, Dry STP	Nm ³	0.686
Sampling Duration	hh:min 00:40	Moisture content of stack gas	% v/v	2.1
		Isokinetic	%	101.6

Impinger	1	2	3	4
Initial mass (g)	678.0	679.7	565.5	947.5
Final mass (g)	676.6	682.1	566.6	957.3

Sample Point Number	Line	Sampling Time hh:min	Pitot Reading (h) mm w.g	Temperatures			Orifice Pressure (Dh) mm w.g
				Sample Gas Temperature (Ts) °C	Filter Temperature °C	Meter Temperature (Tm) °C	
1	A	00:00	1.75	16	158	17	31.0
		00:05	1.75	16	160	17	31.0
		00:10	1.75	16	160	17	31.0
2	A	00:15	2.0	16	160	17	35.0
		00:20	2.0	15	160	17	35.0
		00:25	2.0	15	160	17	35.0
		00:30	2.0	16	160	17	35.0
		00:35	2.0	16	160	17	35.0
		00:40					
		Averages	1.9	15.8	159.8	17.0	33.5

Average velocity	4.76	m/s
Average flow rate	1.44	m ³ /s
Average flow rate	1.33	m ³ /s*

Total Particulate Matter - Sampling Data

Blank Filter Weight		Date of analysis	After (g)	Before (g)	Collected (g)	% of Filter Tare Weight
Filter No	X11379	24/10/2014	0.75280	0.75249	0.00031	
Washings	10401	20/10/2014	48.78087	48.78025	0.00062	0.1

Filter Weight Test 1		Date of analysis	After (g)	Before (g)	Collected (g)	% of Filter Tare Weight
Filter No	X11380	24/10/2014	0.73985	0.74003	-0.00018	
Washings	10402	20/10/2014	47.80151	47.80101	0.00050	0.0

Sample Number	Hopper Or Filter No	Total weights (g)			Control Blank Corrected	Comments
		After	Before	Collected		
Blank	X11379	49.53367	49.53274	0.00093	0.00137	
Test 1	X11380	48.54136	48.54104	0.00032	0.00076	

Washings Control Blank Weight Variance	-0.00044	Acetone Residue Weight	<1ppm
----------------------------------------	----------	------------------------	-------

Particulate emission results	Blank	
Detection Limit	0.71	mg/m ³ *
Particulate Emission	1.96	mg/m ³ *

Particulate Emission Results	Test 1	
Detection Limit	0.71	mg/m ³ *
Particulate Emission	1.09	mg/m ³ *

Total Particulate Matter - Emission Results

Probe/Pitot ID No	P48/PT113	Nozzle Diameter (d)	9.07	mm
Pitot Calibration Factor (Cp)	0.85	In-stack Filtration	N	Y/N
Probe liner material	Titanium	Leak check	Y	Y/N
Gas Calibration Factor (Y)	1.002	Meter ID No	CU13	
Barometric Pressure	kPa 98.9	Initial Gas Meter Reading	5.470	m ³
Duct static Pressure	kPa -0.02	Final Gas Meter Reading	6.188	m ³
Date	14/10/2014	Sampled Vol, Dry at Meter	0.718	m ³
Start Time	hh:min 14:28	Sampled Vol, Dry STP	0.668	Nm ³
End Time	hh:min 15:08	Moisture content of stack gas	1.5	% v/v
Sampling Duration	hh:min 00:40	Isokinetic	99.2	%

Impinger	1	2	3	4	5
Initial mass (g)	679.9	726.3	754.6	583.3	947.5
Final mass (g)	680.0	728.6	755.5	584.0	951.5

Sample Point Number	Line	Sampling Time hh:min	Pitot Reading (h) mm w.g	Temperatures				Orifice Pressure (Dh) mm w.g
				Sample Gas Temperature (Ts) °C	Meter Temperature (Tm) °C	Probe Temperature °C	Filter Temperature °C	
1	A	00:00	2.0	16	14	160	159	35.0
		00:05	2.0	16	14	160	159	35.0
		00:10	2.0	16	14	160	160	35.0
		00:15	2.0	16	15	160	160	35.0
2	A	00:20	1.5	16	16	160	160	26.0
		00:25	1.5	16	16	160	160	26.0
		00:30	2.0	16	16	160	159	35.0
		00:35	2.0	16	16	160	160	35.0
		00:40						
Averages			1.9	16.0	15.1	160.0	159.6	32.8

Average velocity	4.72	m/s
Average flow rate	1.43	m ³ /s
Average flow rate	1.31	m ³ /s*

Lead - Sampling Data

Date	14/10/2014
Start time	14:28
Finish time	15:08
Sample volume Nm ³ (dry gas)	0.668

HEAVY METALS	Impinger mass	
Impinger 1,2 & wash	250.9	g
Impinger 3 & wash	158.2	g

Measured moisture concentration	1.47	% v/v
Measured oxygen concentration	N/A	%

HEAVY METALS	Filter Analysis 2p71962/07	Particulate Phase Emission	Impinger 1 & 2 Analysis 2p71962/08	Vapour phase Emission Impinger 1 & 2	Impinger 3 Analysis 2p71962/09	Vapour phase Emission Impinger 3	Detection Limit	Efficiency % Trapped In impinger 3	Total Emission
Units	µg	mg/m ³ *	µg/l	mg/m ³ *	µg/l	mg/m ³ *	mg/m ³ *	%	mg/m ³ *
Lead (Pb)	4.90	0.00723	4.80	0.00178	1.20	0.00028	0.00092	N/A	0.009288

TOTAL HEAVY METALS Particulate Phase & Vapour Phase	Total Emission mg/m ³ *	Detection Limits mg/m ³ *	Total Emission As % ELV
Total heavy metals, Pb	0.00929	0.00092	1.9

Numbers in bold indicate detection limits

Metals excluding Mercury

Laboratory	SAL	
Method N ^o & Accreditation Status	ICPMS BS EN 14385	UKAS
Date of analysis	29/10/2014	

Lead - Emission Result

Date	14/10/2014
Start time	14:28
Finish time	15:08
Sample volume Nm ³ (dry gas)	0.668

HEAVY METALS	Impinger mass	
Impinger 1,2 & wash	142.9	g
Impinger 3 & wash	146.7	g

Measured moisture concentration	1.47	% v/v
Measured oxygen concentration	N/A	%

HEAVY METALS	Filter Analysis 2p71962/04	Particulate Phase Emission	Impinger 1 & 2 Analysis 2p71962/05	Vapour phase Emission Impinger 1 & 2	Impinger 3 Analysis 2p71962/06	Vapour phase Emission Impinger 3	Detection Limit	Efficiency % Trapped In impinger 3	Total Emission
Units	µg	mg/m ³ *	µg/l	mg/m ³ *	µg/l	mg/m ³ *	mg/m ³ *	%	mg/m ³ *
Lead (Pb)	0.50	0.00000	0.30	0.00000	0.30	0.00000	0.00087	N/A	0.000000

TOTAL HEAVY METALS Particulate phase & Vapour phase	Total Emission mg/m ³ *	Detection Limits mg/m ³ *	Total Emission As % ELV
Total heavy metals, Pb	0.00000	0.00087	0.0

Numbers in bold indicate detection limits

Metals excluding Mercury

Laboratory	SAL	
Method N ^o & Accreditation Status	ICPMS BS EN 14385	UKAS
Date of analysis	29/10/2014	


APPENDIX 3

Diagram Of The Sampling Location

Diagram of sampling points across the cross section of the duct (not to scale).

Traverse length = 0.62 m

Point	% of D	Location cm
1	6.7	4.2
2	25.0	15.5



General Calculations

Stack area:

$$\text{Area of a circle} = \frac{\pi \cdot D^2}{4}$$

D = Diameter (m)

π = 3.142

Pressure conversion:

1mmH2O = 0.00980665 kPa

1mmH2O = 9.80665 Pa

1 mar = 0.1 kPa

Water vapour concentration:

From reference calculations (taken from BS EN 14790):

$$V_{WC(\%)} = \frac{\frac{m_{WC} \cdot V_{mol(std)}}{M_w}}{\frac{m_{WC} \cdot V_{mol(std)}}{M_w} + V_{m(std)}} \times 100$$

WVC (%) = Water vapour content on wet basis, in volume % (m³ of water vapour in m³ of wet gas)

Vm(std) = Dry gas volume measured, corrected to standard conditions (m³)

mWC = Mass of water collected in the impingers (g)

Mw = Molecular weight of water, 18.01534 rounded to 18 (g/mol)

Vmol(std) = Molar volume of water at standard conditions = 0.0224 (m³/mol)

Gas meter volume at standard conditions (STP)

From reference calculations (taken from BS EN 14790):

$$V_{m(std)} = y_d \times (V_2 - V_1) \times \frac{T_{std}}{T_m} \times \frac{P_m}{P_{std}}$$

Vm(std) = Dry gas meter volume at standard conditions (m³)

yd = Gas meter calibration coefficient

(V2-V1) = Dry gas meter volume at actual conditions (m³)

Tm = Actual Temperature (K)

Tstd = Standard temperature (273 K)

pm = Absolute pressure at the gas meter (kPa)

pstd = Standard gas pressure (101.3 kPa)

Isokenetic Ratio (%):

From reference calculations (taken from EA TGN M2):

$$\text{IsokineticRatio}(\%) = \frac{\text{Velocity at the sampling nozzle}}{\text{Velocity of the stack gas}} \times 100$$

Estimating Measurement Uncertainty

Uncertainty estimates are calculated using the general rule of uncertainty propagation. Guidance is taken from publications including UKAS document M3003 and ISO 20988:2007.

Flow Calculations

Velocity:

From reference calculations (taken from ISO 10780):

$$\bar{v} = KC \sqrt{\frac{T_s \Delta p}{p_e M_s}}$$

\bar{v} = Average velocity (m/s)

C = velocity calculation constant = 129

T_s = Average stack temperature (K)

M_s = Molar mass of gas; assume 29 kg/kmol unless the molar mass is < 27 kg/kmol or > 31 g/kmol

K = Pitot calibration coefficient

p_e = Absolute gas pressure (kPa)

Δp = Average pitot tube pressure differential (kPa)

Volume flow rate

From reference calculations (taken from ISO 10780):

$$q_{va} = \bar{v}A$$

q_{va} = Average flow rate (m³/s)

\bar{v} = Average velocity (m/s)

A = Stack cross-sectional area (m²)

Volume flow rate corrected for moisture

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(100 - H_a)}{(100 - H_m)}$$

q_m = Corrected volume flowrate (m³/s)

q_{va} = Volume flow rate at actual conditions (m³/s)

H_a = Moisture at actual conditions (%volume)

H_m = Reference moisture (%volume)

Volume flow rate corrected for temperature and pressure

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(T_m p_a)}{(T_a p_m)}$$

q_m = Corrected volume flowrate (m³/s)

q_{va} = Volume flow rate at actual conditions (m³/s)

T_a = Temperature at actual conditions (K)

T_m = Reference Temperature (K)

p_a = Absolute gas pressure at actual conditions (kPa)

p_m = Reference pressure (kPa)

Volume flow rate corrected for oxygen

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(20.9 - O_{2,ref})}{(20.9 - O_{2,m})}$$

q_m = Corrected volume flowrate (m³/s)

q_{va} = Volume flow rate at actual conditions (m³/s)

$O_{2,m}$ = Actual oxygen concentration (%)

$O_{2,ref}$ = Reference oxygen concentration (%)

Concentration Calculations

Concentration:

From reference calculations (taken from BS EN 13284-1):

$$c = \frac{m}{V}$$

c = Concentration
 m = Mass of substance
 V = Volume sampled

Mass Emission

$$\text{Mass emission} = c \times q_m$$

c = Concentration
 q = Volume flow rate

Concentration corrected for oxygen:

From reference calculations (taken from BS ISO 9096):

$$c_m = c_a \times \frac{20.9 - O_{2,ref}}{20.9 - O_{2,a}}$$

cm = Concentration at reference conditions
 ca = Actual concentration
 O_2, ref = Reference oxygen (%)
 O_2, a = Actual Oxygen (%)

Concentration corrected for moisture:

From reference calculations (taken from BS ISO 9096):

Convert wet gas to dry gas

$$c_{dry} = c_{wet} \times \frac{100}{100 - H_a}$$

Convert dry gas to wet gas

$$c_{wet} = c_{dry} \times \frac{100 - H_a}{100}$$

c_{wet} = Concentration wet gas
 c_{dry} = Concentration dry gas
 H_a = Water vapour content (%vol)

Conversion of parts per million (ppm) to mg/m³

From reference calculations (taken from EA TGN M2):

$$\text{Concentration}(mg / m^3) = \frac{\text{Concentration}(ppm) \times \text{molecular weight}(g)}{\text{molar volume}(l) \text{ at a given temperature}}$$

molar volume at 273K = 22.4 litres

When Converting TOC

$$\text{Concentration}(mg / m^3) = \frac{\text{Concentration}(ppm) \times \text{molecular weight of carbon in span gas}(g)}{\text{molar volume}(l) \text{ at a given temperature}}$$

molar volume at 273K = 22.4 litres

Calculation of Uncertainty Estimates - Manual Monitoring Techniques

$$C_m = \frac{Q_m}{V_{std}}$$

$$V_{std} = V_{T.p} \times \frac{T_{std}}{T} \times \frac{P}{P_{std}}$$

Where:

C_m	=	the measured concentration	in	mg/m ³
Q_m	=	mass concentration collected in absorber solution and filter	in	mg
v_s	=	the volume of the sample solution	in	l
V_{std}	=	volume sampled at standard conditions	in	m ³
T_m	=	mean temperature of gas meter	in	K
T_{std}	=	standard temperature	=	273K
$p=p_{rel}+P_{atm}$	=	absolute pressure = gas meter pressure + atmospheric pressure	in	kPa
P_{std}	=	standard pressure	=	101.325 kPa
$V_{T,p}$	=	volume sampled as indicated by the gas meter	in	m ³

Expression for calculation of the combined uncertainty of the measured concentration

$$\frac{u^2(C_m)}{(C_m)^2} = \frac{u^2(Q_m)}{(Q_m)^2} + \frac{u^2(v_s)}{(v_s)^2} + \frac{u^2(V_{std})}{(V_{std})^2}$$

Expression for calculation of the combined uncertainty of the gas volume

$$V_{std} = V_{T.p} \times \frac{T_{std}}{T_m} \times \frac{P}{P_{std}}$$

Assuming that uncertainties associated with the standard quantities T_{std} and P_{std} are negligible

Expression for calculation of the combined uncertainty of the measured concentration

$$\frac{u^2(C_m)}{(C_m)^2} = \frac{u^2(Q_m)}{(Q_m)^2} + \frac{u^2(v_s)}{(v_s)^2} + \frac{u^2(V_{T.p})}{(V_{T.p})^2} + \frac{u^2(T)}{(T)^2} + \frac{u^2(p_{rel})}{(p)^2} + \frac{u^2(p_{atm})}{(p)^2}$$

$$u(C_m) = \sqrt{\left(\frac{u^2(Q_m)}{(Q_m)^2} + \frac{u^2(v_s)}{(v_s)^2} + \frac{u^2(V_{T.p})}{(V_{T.p})^2} + \frac{u^2(T)}{(T)^2} + \frac{u^2(p_{rel})}{(p)^2} + \frac{u^2(p_{atm})}{(p)^2} \right)} \times (C_m)$$

Overall expanded uncertainty (k = 2)

$$U(C_m) = u(C_m) \times k$$

Uncertainty of the measured concentration at oxygen reference concentration

$$u(C_{m,O_2,ref}) = \sqrt{\left(\frac{u^2(Q_m)}{(Q_m)^2} + \frac{u^2(v_s)}{(v_s)^2} + \frac{u^2(V_{T.p})}{(V_{T.p})^2} + \frac{u^2(T)}{(T)^2} + \frac{u^2(p_{rel})}{(p)^2} + \frac{u^2(p_{atm})}{(p)^2} + \frac{u^2(O_{2,meas,dry})}{(21 - O_{2,meas,dry})^2} \right)} \times (C_{m,O_2,ref})$$

Where:

$u(C_{m,O_2,ref})$	=	uncertainty associated with the mass concentration at O ₂ reference concentration	in	mg/m ³
$C_{m,O_2,ref}$	=	mass concentration at O ₂ reference concentration	in	mg/m ³
$O_{2,meas}$	=	O ₂ measured concentration	in	% volume
$u(O_{2,meas,dry})$	=	uncertainty associated to the measured O ₂ concentration	in	% (relative to O _{2,meas})

APPENDIX 4

Uncertainty Estimate For The Measurement Of Total Particulate Matter BS EN 13284 - 1

Total Particulate Matter Test 1

Symbol	Mass concentration of TPM	Units
C_m	1.11	mg/m ³
C_m at O ₂ ref	N/A	mg/m ³

Filter	-0.18	mg
Washings	0.50	mg

Symbol	Reference Oxygen	Units
O _{2,ref} (0=No Correction)	0	%

Symbol	Daily emission limit value	Units
DELV	20.0	mg/m ³

Mass of Particulate

Symbol	Source of Uncertainty	Value	Units	Probability Distribution	Divisor	c_i	U_i	
$u(\text{calBal})$	Calibration	0.1180	mg	Normal	2	1	0.0590	
$u(\text{repBal})$	Repeatability Filter	0.0110	mg	Normal	1	2	0.0220	
$u(\text{repBal})$	Repeatability Washings	0.0300	mg	Normal	1	2	0.0600	
$u(\text{driftBal})$	Drift	0.0312	mg	Rectangular	$\sqrt{3}$	1	0.0180	
$u(\text{resBal})$	Resolution	0.0050	mg	Rectangular	$\sqrt{3}$	1	0.0029	
$u(\text{aceBal})$	Residual acetone	0.0400	mg	Normal	2	1	0.0200	
$u(\text{buoBal})$	Air buoyancy	0.0015	mg	Normal	1	1	0.0015	
$u(\text{mass})$	Combined Uncertainty	-	-	Normal	-	-	0.0911	
$u(\text{mass})/\text{mass}$	Relative	0.760	mg	-	-	-	0.0822	
							$u(\text{mass})^2/\text{mass}^2$	0.006755

U(Wm)	Expanded Combined Weighing Uncertainty As Percentage of DELV k=2		±	0.91	%
-------	------------------------------------------------------------------	--	---	------	---

Volume of sampled gas

Symbol	Source of Uncertainty	Value	Units	Probability Distribution	Divisor	c_i	U_i	
$u(\text{calV}_{T,p})$	Calibration	0.0034	m ³	Normal	2	1	0.0017	
$u(\text{repV}_{T,p})$	Repeatability	0.0003	m ³	Normal	1	1	0.0003	
$u(\text{driftV}_{T,p})$	Drift	0.0019	m ³	Rectangular	$\sqrt{3}$	1	0.0011	
$u(\text{resV}_{T,p})$	Resolution	0.0002	m ³	Rectangular	$\sqrt{3}$	1	0.0001	
$u(V_{T,p})$	Combined Uncertainty	-	-	Normal	-	-	0.0020	
$u(V_{T,p})/V_{T,p}$	Relative	0.686	m ³	-	-	-	0.0030	
							$u(V_m)^2/V_m^2$	0.000009

Temperature of the DGM

Symbol	Source of Uncertainty	Value	Units	Probability Distribution	Divisor	c_i	U_i	
$u(\text{calT}_m)$	Calibration	1.0	K	Normal	2	1	0.5000	
$u(\text{calT}_m)$	Calibration	1.0	K	Normal	2	1	0.5000	
$u(\text{resT}_m)$	Resolution	0.1	K	Rectangular	$\sqrt{3}$	1	0.0577	
$u(\text{driftT}_m)$	Drift	1.0	K	Rectangular	$\sqrt{3}$	1	0.5774	
$u(T_m)$	Combined Uncertainty	-	-	Normal	-	-	0.9147	
$u(T_m)/T_m$	Relative	290.0	K	Normal	-	-	0.0032	
							$u(T_m)^2/T_m^2$	0.000010

Atmospheric Pressure

Symbol	Source of Uncertainty	Value	Units	Probability Distribution	Divisor	c_i	U_i	
$u(P_{\text{atm}})$	Metrological Office	300	Pa	Normal	$\sqrt{3}$	1	173	
$u(P_{\text{atm}})$	Combined Uncertainty	-	-	Normal	-	-	173	
$u(P_{\text{atm}})/P$	Relative	98900	-	Normal	-	-	0.0018	
							$u(P_{\text{atm}})^2/P^2$	0.000003

Relative DGM Pressure

Symbol	Source of Uncertainty	Value	Units	Probability Distribution	Divisor	c_i	U_i	
$u(P_{\text{rel}})$	DGM Pressure	40	Pa	Normal	1	1	40	
$u(P_{\text{rel}})$	Combined Uncertainty	-	-	Normal	-	-	40	
$u(P_{\text{rel}})/P$	Measured pressure	99229	-	-	-	-	0.0004	
							$u(P_{\text{rel}})^2/P^2$	0.0000002

Oxygen reference concentration

Symbol	Source of Uncertainty	Value	Units	Probability Distribution	Divisor	c_i	U_i	
$u((\text{O}_2, \text{meas})_{\text{dry}})_{\text{rel}}$	Measurement of oxygen	N/A	%	Normal	1	1	N/A	
	Uncertainty of oxygen correction	-	-	-	-	-	N/A	
	Measured Oxygen	N/A	%	-	-	-	$u(\text{Orel})^2/\text{O}^2$	
								N/A

Measurement uncertainty

$u(C_m)$	Combined Standard Uncertainty			±	0.13	mg/m ³
$u(C_m)$ at ref O ₂	Combined Standard Uncertainty			±	N/A	mg/m ³

Expanded uncertainty expressed with a level of confidence of 95%, k=2

U(Cm)	Expanded Combined Uncertainty	k = 2		±	0.26	mg/m ³
U(Cm,rel)	Expanded Combined Uncertainty	k = 2		±	23.3	%
U(Cm,rel,ELV)	Expanded Combined Uncertainty	k = 2		±	1.3	%

Expanded uncertainty at oxygen reference conditions expressed with a level of confidence of 95%, k=2

U(Cm) at ref O ₂	Expanded Combined Uncertainty	k = 2		±	N/A	mg/m ³
U(Cm,rel) at ref O ₂	Expanded Combined Uncertainty	k = 2		±	N/A	%
U(Cm,rel,ELV) at ref O ₂	Expanded Combined Uncertainty	k = 2		±	N/A	%

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor (k = 2), providing a level of confidence of approximately 95%

The uncertainty evaluation has been carried out in accordance with UKAS requirements.

Uncertainty Estimate For The Measurement Of Heavy Metals BS EN 14385 - Lead

Total Mass Concentration Of Metals

Symbol	Total mass concentration of Lead	Units
Cm	0.00943	mg/m ³
Cm at O2 ref	N/A	mg/m ³

Mass of heavy metals in filter digest

	Qmf (mg)	LODmf	u(Qmf) % (k = 2)	u(Qmf)/Qmf	u(Qmf) ² /Qmf ²
Lead (Pb)	4.900	0.500	23.000	0.115	0.013

Concentration of heavy metals absorption solution

	Qm (mg/l)	LODm	u(Qm) % (k = 2)	u(Qm)/Qm	u(Qm) ² /Qm ²
Lead (Pb)	4.800	0.300	20.500	0.103	0.011

Volume of sampled gas

Symbol	Source of Uncertainty	Value	Units	Probability Distribution	Divisor	ci	Ui
u(calVT.p)	Calibration	0.0028	m ³	Normal	1.000	1.000	0.003
u(driftVT.p)	Drift	0.0027	m ³	Rectangular	$\sqrt{3}$	1.000	0.002
u(resVT.p)	Resolution	0.0002	m ³	Rectangular	$\sqrt{3}$	1.000	0.000
u(VT.p)	Combined Uncertainty	-	-	Normal	-	-	0.003
u(VT.p)/VT.p	Relative uncertainty	0.668	m ³	-	-	-	0.005
						u(Vm) ² /Vm ²	0.000023

Temperature of the DGM

Symbol	Source of Uncertainty	Value	Units	Probability Distribution	Divisor	ci	Ui
u(calTm)	Calibration	1.0	K	Normal	2.000	1.000	0.500
u(calTcm)	Calibration	1.0	K	Normal	2.000	1.000	0.500
u(resTm)	Resolution	0.5	K	Rectangular	$\sqrt{3}$	1.000	0.289
u(Tm)	Combined Uncertainty	-	-	Normal	-	-	0.764
u(Tm)/Tm	Relative uncertainty	288	K	Normal	-	-	0.003
						u(Tm) ² /Tm ²	0.000007

Atmospheric Pressure

Symbol	Source of Uncertainty	Value	Units	Probability Distribution	Divisor	ci	Ui
u(Patm)	Metrological Office	300	Pa	Normal	1.000	1.000	300
u(Patm)	Combined Uncertainty	-	-	Normal	-	-	300
u(Patm)/P	Relative uncertainty	98900	-	Normal	-	-	0.003
						u(Patm) ² /P ²	0.000009

Relative DGM Pressure

Symbol	Source of Uncertainty	Value	Units	Probability Distribution	Divisor	ci	Ui
u(Prel)	Manometer	40	Pa	Normal	1.000	1.000	40.000
u(Prel)	Combined Uncertainty	-	-	Normal	-	-	40.000
u(Prel)/P	Relative uncertainty	99221	-	Normal	-	-	0.0004
						u(Prel) ² /P ²	0.0000002

Volume (mass) of Absorption Solution

Symbol	Source of Uncertainty	Value	Units	Probability Distribution	Divisor	ci	Ui
u(repsvs)	Repeatability	0.13	g (ml)	Normal	1.000	1.000	0.130
u(calvs)	Calibration (Tare)	0.10	g (ml)	Rectangular	1.000	1.000	0.100
u(drvs)	Drift	0.10	g (ml)	Rectangular	1.000	1.000	0.100
u(resvs)	Resolution	0.05	g (ml)	Rectangular	$\sqrt{3}$	1.000	0.029
u(vs)	Combined Uncertainty	-	-	-	-	-	0.194
u(vs)/vs	Relative uncertainty	251	-	Normal	-	-	0.0008
						u(vs) ² /vs ²	0.0000006

u(Cm)rel	Overall Combined Uncertainty	mg/m ³	Total Lead	±	0.0015
----------	------------------------------	-------------------	------------	---	--------

U(Cm)rel	Expanded Combined Uncertainty	mg/m ³	Total Lead	k = 2	±	0.0029
U(Cm,rel)	Expanded Combined Uncertainty	% of ELV	Total Lead	k = 2	±	0.1

u(Cmrel) at ref O2	Expanded Combined Uncertainty	mg/m ³	Total Lead	k = 2	±	N/A
U(Cm,rel)	Expanded Combined Uncertainty	% of ELV	Total Lead	k = 2	±	N/A

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor (k = 2), providing a level of confidence of approximately 95%.

The uncertainty evaluation has been carried out in accordance with UKAS requirements.