


KEY.
 PUMP SUCTION LINES INDICATED THUS: —
 OFFSET FILL LINES " " —
 VENT LINES " " —

ALL PIPELINES SHOWN DIAGRAMMATICALLY ONLY.

NOTE.
 1. EACH EX' AND NEW TANK LID TO HAVE 1" b.s.p. conn' FOR TANKMASTE ELECTRONIC GAUGE EQUIPMENT.
 2. ALL UNDERGROUND PIPEWORK TO BE SURROUNDED WITH A MIN' 150mm SULPHATE RESISTANT CONCRETE. (by builder).



rev.	date	dm.	details
 Esso Petroleum Company Ltd Midland Region, Aldridge Road, Little Aston Sutton Coldfield West Midlands 021 353 2424			
Service Station		No.	
MOSSGROVE S/STN		2131	
Title			
PIPEWORK LAYOUT			
Drawn	Date	Scale	Drawing No.
P.	DEC '81	1:100	2131/11/81/3
Checked			

Scale reduced